

Workorder Summary Report

Report Start Date: Oct 1, 2020 12:00 AM  
Report End Date: Oct 31, 2020 11:59 PM  
Location: 1103\*  
Work Order Type: ADMIN,CALL,CAP,CORR,EMER,OPER,PM  
Work Order Class:

				WorkOrder		PM Schedule		Workorder Details					
WO #	Asset ID	Asset Description	Location Description	Type	Class	FEQ	Units	Work Order Description	Status	Schedule Start	Actual Start	Actual Finsh	WorkLog Detail
<a href="#">1955791</a>	0000227376	PANEL ALARM/ DIALER	1103, Fort Frances WPCP, Process, Process Control & Monitoring	PM	Inspection	1	MONTHS	Critical Alarm/Dialer Testing (1m) 1103	COMP	10/1/20 12:00 AM	10/24/20 11:00 AM	10/24/20 12:00 PM	Dialer Test -We test daily at 11 .
<a href="#">1955795</a>			1103, Fort Frances WPCP	PM	Refurbish/ Replace/Repair	1	MONTHS	Diesel Gensets Inspection/ Functional Tests (1m) 1103	COMP	10/1/20 12:00 AM	10/27/20 07:31 AM	10/27/20 07:31 AM	Monthly Genset Testing -I ran each genset under load for one hour.
<a href="#">1955811</a>			1103, Fort Frances WPCP	PM	Health and Safety	1	MONTHS	Health And Safety Inspection (1m) 1103	COMP	10/1/20 12:00 AM	10/27/20 07:32 AM	10/27/20 07:32 AM	Monthly H&S -No Issues this month.
<a href="#">1955822</a>			1103, Fort Frances WPCP	PM	Inspection	1	MONTHS	TPM Inspection/Maintenance (1m) 1103	COMP	10/1/20 12:00 AM	11/4/20 03:03 PM	11/4/20 03:03 PM	
<a href="#">1956149</a>			1103, Fort Frances WPCP	PM	Inspection	1	MONTHS	Blowers/Motors Inspection/Service (1m/3m) 1103	COMP	10/1/20 12:00 AM	10/26/20 09:30 AM	10/26/20 11:30 AM	Monthly Blower Maint -I changed oil in blowers 3 & 4 and greased blower 2 & 5 .
<a href="#">1956157</a>	0000246402	CENTRIFUGE GS2-2-1 TEACUP/ GRIT SNAIL	1103, Fort Frances WPCP, Process, Primary Treatment, Primary Sludge Degritting	PM	Inspection	1	MONTHS	Teacup Centrifuge Inspection/ Service (1m/3m/1y) 1103	COMP	10/1/20 12:00 AM	11/2/20 07:07 AM	11/2/20 07:07 AM	
<a href="#">1956844</a>	0000129813	ANALYZER MONITOR DISSOLVED OXYGEN MAIN BUILDING	1103, Fort Frances WPCP, Process, Process Control & Monitoring, Secondary Treatment	PM	Inspection	6	MONTHS	Analyzer Monitor DO Inspection (6m) 1103	COMP	10/1/20 12:00 AM	10/30/20 01:58 PM	10/30/20 01:58 PM	Analyzer Monitor DO Inspection (6m) 1103 -Cleaned the DO probes, Kelly C
<a href="#">1962733</a>	0000129958	PANEL CONTROL FLOW/ALARM	1103, White Pine Pumping Station, Facility	CALL	Refurbish/ Replace/Repair	0		White Pine PLC Failure 1103	COMP		10/24/20 01:30 AM	10/24/20 04:45 AM	White Pine PLC Failure 1103 -I was called by Dale Hughes at 0130 hours on October 24, 2020 to assist with a PLC failure at White Pine lift station. Once we replaced the power supply in the PLC the station returned to proper operation.
<a href="#">1962742</a>	0000129960	PANEL CONTROL PUMP	1103, White Pine Pumping Station, Facility	CALL	Refurbish/ Replace/Repair	0		White Pine PLC Failure 1103	COMP		10/24/20 12:20 PM	10/24/20 12:28 PM	White Pine PLC Failure -I arrived at the lift station and noticed plc to be acting different. I then called Kelly in because I could not leave the station due to manual pumping . We then replaced the PLC power supply card and the station came back normal again.