

**TOWN OF FORT FRANCES**  
**Operations and Facilities Division - Environmental Area - Operations Statistics**  
**(June 2017)**

**STAFFING:**

See Operations Statistics (June) 2017 prepared by M. Strachan, Superintendent of Transportation

**OVERTIME HOURS - Equivalent Straight Time Hours**

See Operations Statistics (June) 2017 prepared by M. Strachan, Superintendent of Transportation

**WATER DISTRIBUTION:**

Water Main Breaks:

- Number of water main breaks: None

Hydrant Repairs:

- Number of hydrant repairs: Seven (7)
  - Calder Dr. next to Point Park showers (HYD330), 1112 Fifth St. E. (HYD229), 924 Sixth St. E. (HYD270)
  - 1128 Fourth St. E. (HYD298), 824 Armit Ave. (HYD253), 940 Fourth St. E. (HYD285)
  - and Eighth St. E. at Mill Road (HYD327)

Hydrant Replacements:

- Number of hydrant replacements: None

Hydrant Installations (NEW):

- Number of new hydrant installations: None

Main Valve Repairs:

- Number of water main valve repairs: Five (5)
  - Fifth St. E. at Shevlin Ave. (VAL463), Fifth St. E. at CNR (VAL325), CNR at Crowe Ave. (VAL631)
  - Cornwall Ave. at Fifth St. W. (VAL182) and Second St. E. at Crowe Ave. (VAL391)

Main Valve Replacements:

- Number of water main valve replacements: None

Water Service Breaks:

- Number of water service breaks: None

Water Service Repairs:

- Number of water service repairs: Eight (8)
  - 1035 Cornwall Ave. N., 800 McKenzie Ave., 1008 Walker Ave., 108 Sixth St. E., 410 Sinclair St.,
  - 1005 Fifth St. E., 320 Second St. E. and 1044 Cornwall Ave. N.

Water Service Installations (NEW):

- Number of water service installations: One (1)
  - 650 Sixth St. W.

Water Service Replacements:

- Number of water service replacements: None

Water Service Terminations:

- Number of water service terminations: None

Water Service Turn "Off/On":

- Number of water service turn "Off/On": Five (5)
  - 145 Third St. W., 1214 Third St. E., 1005 Fifth St. E. (2) and 1044 Cornwall Ave. N.

Frozen Water Services:

- Number of frozen water services: None

Water Meter Installations/Replacements:

- Number of water meter installations/replacements: Two (2)
  - 1533 King's Hwy. and 411 McIrvine Rd.

Backflow Preventer Installations/Replacements:

- Number of backflow preventer installations/replacements: One (1)
  - 411 McIrvine Rd.

Backflow Prevention - Testing:

- Number of backflow preventers tested: Four (4)
  - 921 Sixth St. W., 237 Fifth St. E., 1533 King's Hwy. and 411 McIrvine Rd.

Other Information:

- Summarized final costs for invoicing of private works associated with private works
- June 14, 2017 - G. Wiedenhoef attended a course "Working from Heights" at the La Place Rendez-vous.
- June 19, 2017 - Bay City started construction works at Nelson St.
- Continued with the valve exercising program (Area 1) and hydrant valve exercising.
- Recorded locations of curb stops at various locations.
- Worked in conjunction with Bay City to isolate the existing water main, disinfect and test water quality before putting the temporary water service lines on Nelson St. into service.
- Replaced missing and faded markers on fire hydrants.

**WATER TREATMENT PLANT:**

- June, 2017 - In receipt of the Water Treatment Facility Monthly Report.
- June 14, 2017 - P. Lemesurier attended a course "Working from Heights" at the La Place Rendez-vous.
- June 19 - 23, 2017 - B. Webb attended a course Water Distribution - Class 1-3 held at the Keewaytinook Centre of Excellence in Dryden.

**SEWERAGE COLLECTION:**

Wastewater Main Backups:

- Number of wastewater main backup: One (1)
  - Flinders Ave. (500 blk.)

Wastewater Main Repairs:

- Number of wastewater main repairs: None

Wastewater Manhole Repairs:

- Number of wastewater manhole repairs: None

Sewer Service Repairs:

- Number of sewer service repairs: One (1)
  - Sinclair St. - 410

Sewer Service Replacements:

- Number of sewer service replacements: None

Sewer Service Installations (NEW):

- Number of sewer service installations: One (1)
  - Sixth St. W. - 650

Sewer Service Terminations:

- Number of water service terminations: None

Other Information:

- Cleaned eight (8) plugged sewer services at the following locations:
  - 629 Third St. E., 900 Armit Ave., 650 Third St. E., 400 Third St. E., 1332 Sixth St. E., 410 Sinclair St.
  - 512 Front St. and 916 Victoria Ave. N.
- June 16, 2017 - Cambrian commenced the cleaning and televising the sanitary sewer mains
- June 20, 2017 - Connection inspection of the water service at 320 Second St. E.
- June 20, 2017 - Television inspection of the water service at 916 Victoria Ave. N.
- June 22 - 23, 2017 - Cleaned sanitary sewer mains for the Township of Barwick (Chapple)
- June 26, 2017 - Assisted Bay City in exposing valves using vactor truck.
- June 29, 2017 - Cleaned sanitary sewer mains for the community of Rainy River
- Recorded locations of cleanouts at various locations.

**WASTE-WATER TREATMENT FACILITY:**

- June 2017 - In receipt of the Wastewater Treatment Facility Monthly Report.

**WASTE MANAGEMENT:**

Garbage Collection:

- Number of complaints regarding garbage collection:
  - Town - 0 complaints, Asselin's - 8 complaints

Sanitary Landfill (Waste Disposal Site):

Landfill Scales functioning properly during this period.

- Amount of residential waste delivered to the landfill:
  - 314,600 kgs (314.60 tonnes)
- Amount of ICI waste delivered to the landfill:
  - 341,840 kgs (341.84 tonnes)
- June 2017 - Bay City hauled material from their respective construction sites to the landfill - cover material.
- June 15, 2017 - Weigh-Tronix on site to check weigh scales (issue with weights)

Recycling:

- Number of complaints regarding recycled materials:
  - Town - 0 complaints, Asselin's - 2 complaints
- Amount of recycled waste diverted from the landfill:
  - No Data - Emterra

Prepared By: \_\_\_\_\_

Environmental & Facilities Superintendent

Date: \_\_\_\_\_