

Workorder Summary Report

Report Start Date: Jan 1, 2022 12:00 AM  
Report End Date: Jan 31, 2022 11:59 PM  
Location: 1103\*  
Work Order Type: ADMIN,CALL,CAP,CORR,EMER,OPER,PM  
Work Order Class:

				WorkOrder		PM Schedule		Workorder Details					
WO #	Asset ID	Asset Description	Location Description	Type	Class	FEQ	Units	Work Order Description	Status	Schedule Start	Actual Start	Actual Finsh	WorkLog Detail
<a href="#">2614564</a>			1103, Fort Frances WPCP	OPER	Inspection	1	MONTHS	Snow Removal at Wastewater Treatment (1m) 1103	COMP	1/1/22 12:00 AM	2/7/22 09:05 AM	2/7/22 09:05 AM	
<a href="#">2629524</a>	0000227376	PANEL ALARM/DIALER	1103, Fort Frances WPCP, Process, Process Control & Monitoring	PM	Inspection	1	MONTHS	Critical Alarm/Dialer Testing (1m) 1103	COMP	1/1/22 12:00 AM	1/31/22 09:22 AM	1/31/22 09:22 AM	Dialer Test -We test daily at 11 am.
<a href="#">2629528</a>			1103, Fort Frances WPCP	PM	Refurbish/Replace/Repair	1	MONTHS	Diesel Gensets Inspection/Functional Tests (1m) 1103	COMP	1/1/22 12:00 AM	1/30/22 10:15 AM	1/30/22 11:15 AM	Monthly Gensets -I ran the genset at the plant for one hour.
<a href="#">2629545</a>			1103, Fort Frances WPCP	PM	Health and Safety	1	MONTHS	Health And Safety Inspection (1m) 1103	COMP	1/1/22 12:00 AM	2/1/22 06:30 AM	2/1/22 07:30 AM	H&S Inspection -Plow truck rust is still an issue.
<a href="#">2629556</a>			1103, Fort Frances WPCP	PM	Inspection	1	MONTHS	TPM Inspection/Maintenance (1m) 1103	COMP	1/1/22 12:00 AM	2/7/22 09:04 AM	2/7/22 09:04 AM	
<a href="#">2629967</a>			1103, Fort Frances WPCP	PM	Inspection	1	MONTHS	Blowers/Motors Inspection/Service (1m/3m) 1103	COMP	1/1/22 12:00 AM	1/31/22 06:30 AM	1/31/22 07:30 AM	Blower Maint. -I greased all blowers.
<a href="#">2629975</a>	0000246402	CENTRIFUGE GS2-2-1 TEACUP/GRIT SNAIL	1103, Fort Frances WPCP, Process, Primary Treatment, Primary Sludge Degritting	PM	Inspection	1	MONTHS	Teacup Centrifuge Inspection/Service (1m/3m/1y) 1103	COMP	1/1/22 12:00 AM	1/31/22 07:30 AM	1/31/22 08:30 AM	Teacup Maint -I greased all bearings.
<a href="#">2633840</a>	0000227447	PUMP CENT #1 VERTICAL NON CLOG SEWAGE P1 WHITEPINE	1103, White Pine Pumping Station, Process	CALL	Refurbish/Replace/Repair	0		White Pine P1 Failure 1103	COMP		1/1/22 01:46 PM	1/1/22 01:52 PM	White Pine P1 Failure Alarm -I went to White Pine lift station and reset the pump then returned to the plant and monitored many pump cycles. Still awaiting parts to repair problem.
<a href="#">2633841</a>	0000227360	MOTOR PUMP DIGESTER SLUDGE #1	1103, Fort Frances WPCP, Process, Sludge Treatment & Handling, Sludge Digestion	CALL	Refurbish/Replace/Repair	0		Digester Low Temp Alarm 1103	COMP		1/1/22 01:54 PM	1/1/22 02:00 PM	Digester Low Temp Alarm -I arrived onsite to find that the portable heater had failed and tripped the breaker. I then replaced the heater with a new unit and reset the breaker and waited until I could see the temp rise on SCADA.
<a href="#">2634136</a>	0000227447	PUMP CENT #1 VERTICAL NON CLOG SEWAGE P1 WHITEPINE	1103, White Pine Pumping Station, Process	CALL	Refurbish/Replace/Repair	0		White Pine P1 Failure 1103	COMP		1/2/22 11:37 AM	1/2/22 11:43 AM	White Pine P1 Failure Alarm -I reset the pump at the plant and at the lift station then monitored many pump cycles. Still awaiting parts to repair.

Workorder Summary Report

Report Start Date: Jan 1, 2022 12:00 AM

Report End Date: Jan 31, 2022 11:59 PM

Location: 1103\*

Work Order Type: ADMIN,CALL,CAP,CORR,EMER,OPER,PM

Work Order Class:

				WorkOrder		PM Schedule		Workorder Details					
WO #	Asset ID	Asset Description	Location Description	Type	Class	FEQ	Units	Work Order Description	Status	Schedule Start	Actual Start	Actual Finsh	WorkLog Detail
<a href="#">2634266</a>	0000227447	PUMP CENT #1 VERTICAL NON CLOG SEWAGE P1 WHITEPINE	1103, White Pine Pumping Station, Process	CALL	Refurbish/ Replace/Repair	0		White Pine P1 Failure 1103	COMP		1/3/22 12:04 PM	1/3/22 12:22 PM	White Pine P1 Failure Alarm -I arrived onsite and reset the alarm on SCADA then I confirmed that P2 was running so I left P2 as lead pump for the day until I leave then I will need to switch them back as it will continue to call.
<a href="#">2634503</a>	0000227447	PUMP CENT #1 VERTICAL NON CLOG SEWAGE P1 WHITEPINE	1103, White Pine Pumping Station, Process	CALL	Refurbish/ Replace/Repair	0		White Pine P1 Failure 1103	COMP		1/4/22 07:12 AM	1/4/22 07:17 AM	White Pine P1 Failure -I reset the pump. Hopefully the contractor will have the parts to repair tomorrow.
<a href="#">2634505</a>	0000227447	PUMP CENT #1 VERTICAL NON CLOG SEWAGE P1 WHITEPINE	1103, White Pine Pumping Station, Process	CALL	Refurbish/ Replace/Repair	0		White Pine P1 Failure Alarm 1103	COMP		1/4/22 07:19 AM	1/4/22 07:23 AM	White Pine P1 Failure -I reset the pump and it acted normal.
<a href="#">2636426</a>	0000227447	PUMP CENT #1 VERTICAL NON CLOG SEWAGE P1 WHITEPINE	1103, White Pine Pumping Station, Process	CALL	Refurbish/ Replace/Repair	0		White Pine Genset Fault 1103	COMP		1/13/22 07:59 AM	1/13/22 08:06 AM	White Pine Genset Fault -I arrived at the lift station to find the power out and the genset had a low oil pressure alarm. After checking all connections I added oil to the engine and it still would not clear, So I played with the reset and run switches and it reset and tried to start and failed again. I then tried to reset the switches and after a minute or so it reset and started. I will need to check the switches when we run it next.
<a href="#">2637160</a>	0000246428	PUMP CENT BOUNDARY P1	1103, Boundary Pumping Station, Process	CALL	Refurbish/ Replace/Repair	0		Boundary P1 Failure Alarm 1103	COMP		1/17/22 07:01 AM	1/17/22 07:06 AM	Boundary P1 Failure Alarm -I went to the lift station and reset the main breaker then I tried both pumps on hand and they operated like normal. I then returned to the plant and monitored a few pump cycles.

Workorder Summary Report

Report Start Date: Jan 1, 2022 12:00 AM

Report End Date: Jan 31, 2022 11:59 PM

Location: 1103\*

Work Order Type: ADMIN,CALL,CAP,CORR,EMER,OPER,PM

Work Order Class:

				WorkOrder		PM Schedule		Workorder Details					
WO #	Asset ID	Asset Description	Location Description	Type	Class	FEQ	Units	Work Order Description	Status	Schedule Start	Actual Start	Actual Finsh	WorkLog Detail
<a href="#">2637995</a>			1103, Fort Frances WPCP, Process, Sludge Treatment & Handling, Sludge Digestion	CALL	Refurbish/ Replace/Repair	0		Low temperature alarm digester building call in 1103	COMP		1/20/22 04:20 AM	1/20/22 06:15 AM	Low temperature alarm digester building call in 1103 -At 0420 hours I was called by the auto dialer for a digester building low temperature alarm. I drove to the plant where I acknowledged alarms on the SCADA computer. Then I confirmed that there was power to the heaters but had to replace 1 small heater that had no fan function. Shortly thereafter it was fine.