

ID	Origin ID	Department	Work Order Type Group	Work Order Type	Work Order Subtype	Status	Assigned To	Created Date	Completed Date	Customer Name	Most Recent Note	Asset ID
WO-3716		Com Serv - MSC	Memorial Sport Centre	General Maintenance - MSC		Completed	Jim Garvie	2/25/2020 15:24	2/26/2020 11:11		Repair the floor mats in the 52 change room hall way	
WO-3715		Com Serv - Museum	Museum	General Maintenance-Museum	HVAC Maintenance	Completed	Jim Garvie	2/25/2020 15:21	2/25/2020 15:22		Clean drain valve for the Honeywell humidifier in the basement	
WO-3714		Com Serv - MSC	Memorial Sport Centre	General Maintenance - MSC		Completed	Jim Garvie	2/24/2020 14:27	2/27/2020 15:31		Replace 2 fire extinguisher cabinets in the 52 lobby	
WO-3713		Com Serv - Library	Library	General Maintenance - Library	Carpentry	Completed	Jim Garvie	2/24/2020 12:46	2/24/2020 12:47		Replace the sharps container in the woman's handicap washroom	
WO-3710		Com Serv - East End Hall	East End Hall	General Maintenance-East End Hall		Completed	Jim Garvie	2/13/2020 11:21	2/13/2020 11:21		Repair door latch	
WO-3708		Com Serv - Library	Library	General Maintenance - Library	Plumbing Maintenance	Completed	Jim Garvie	2/13/2020 7:31	2/13/2020 10:07		Repair the toilet in the men's washroom	
WO-3707		Com Serv - MSC	Memorial Sport Centre	General Maintenance - MSC		Completed	Jim Garvie	2/12/2020 14:58	2/19/2020 14:46		Remove old piping from the 52 rink compressor room	
WO-3706		Com Serv - MSC	Memorial Sport Centre	General Maintenance - MSC		Completed	Jim Garvie	2/11/2020 11:18	2/12/2020 14:55		Repair various items in the pool chemical room	
WO-3693		Com Serv - MSC	Memorial Sport Centre	Bench Monthly Detail Inspection		Completed	Jim Garvie	2/7/2020 15:32	2/10/2020 12:03		Replace the double sink drain pipes for the snack kitchen	
WO-3692		Ops & Fac - Public Works	Public Works	General Maintenance-PW		Completed	Jim Garvie	2/7/2020 7:34	2/7/2020 11:00		Replace burnt out bulbs in the front conference room lights.	
WO-3691		Com Serv - MSC	Memorial Sport Centre	General Maintenance - MSC		Completed	Jim Garvie	2/6/2020 15:43	2/7/2020 15:30		Repair lifted flooring in the weight room	
WO-3690		Com Serv - MSC	Memorial Sport Centre	General Maintenance - MSC		Completed	Jim Garvie	2/6/2020 14:49	2/6/2020 14:49		Replace 5 toilet paper dispensers	
WO-3689		Com Serv - MSC	Memorial Sport Centre	General Maintenance - MSC		Completed	Jim Garvie	2/5/2020 12:05	2/6/2020 14:45		Repair the entry way hand rail	
WO-3688		Civic Centre	Civic Centre	General Maintenance - Civic Centre	Carpentry	Completed	Jim Garvie	2/4/2020 12:05	2/4/2020 13:32		Repair the middle garage door for the OPP garage	
WO-3687		Com Serv - Sister Kennedy	Sister Kennedy Centre	General Maintenanc-Sister Kennedy	Carpentry	Completed	Jim Garvie	2/4/2020 9:05	2/4/2020 15:23		Install dead bolt for the carpenter shop	
WO-3684		Com Serv - East End Hall	East End Hall	Daily Inspection		Completed	Jim Garvie	1/31/2020 7:30	2/28/2020 15:37		Inspect East End Hall, Weight Scale, Marina, Tourist Information Building, Old Library, Old Nursing Station. and the old daycare.	
WO-3683		Com Serv - MSC	Memorial Sport Centre	Bench Monthly Detail Inspection		Completed	Jim Garvie	1/31/2020 7:28	2/5/2020 12:02		Install 2 cabinets for the I. T. folks	
WO-3644	PM-3534	Ops & Fac - Fort Frances Muni Airport	Airport	Monthly Inspection-Airport	Check Oil Level, Drain Water	Completed	Mike Beyak	1/20/2020 17:18	2/9/2020 15:14			21841
WO-3643	PM-3533	Ops & Fac - Fort Frances Muni Airport	Airport	Monthly Inspection-Airport	Visual Inspection	Completed	Mike Beyak	1/20/2020 17:18	2/9/2020 15:13			21839
WO-3642	PM-3532	Ops & Fac - Fort Frances Muni Airport	Airport	Monthly Inspection-Airport	Visual Inspection	Completed	Mike Beyak	1/20/2020 17:17	2/9/2020 15:13			21840
WO-3641	PM-3531	Ops & Fac - Fort Frances Muni Airport	Airport	Monthly Inspection-Airport	Visual Inspection	Completed	Mike Beyak	1/20/2020 17:17	2/9/2020 15:14			21845
WO-3640	PM-3530	Ops & Fac - Fort Frances Muni Airport	Airport	Monthly Inspection-Airport	Visual Inspection	Completed	Mike Beyak	1/20/2020 17:17	2/9/2020 15:14			21843
WO-3639	PM-3529	Ops & Fac - Fort Frances Muni Airport	Airport	Monthly Inspection-Airport	Visual Inspection	Completed	Mike Beyak	1/20/2020 17:16	2/9/2020 15:15			21842
WO-3638	PM-3528	Ops & Fac - Fort Frances Muni Airport	Airport	Monthly Inspection-Airport	Visual Inspection	Completed	Mike Beyak	1/20/2020 17:16	2/9/2020 15:15			21838
WO-3637	PM-3527	Ops & Fac - Fort Frances Muni Airport	Airport	Monthly Inspection-Airport	Visual Inspection	Completed	Mike Beyak	1/20/2020 17:16	2/9/2020 15:16			21837
WO-3636	PM-3526	Ops & Fac - Fort Frances Muni Airport	Airport	Monthly Inspection-Airport	Visual Inspection	Completed	Mike Beyak	1/20/2020 17:15	2/9/2020 15:16			21836
WO-3635	PM-3525	Ops & Fac - Fort Frances Muni Airport	Airport	Monthly Inspection-Airport	Visual Inspection	Completed	Mike Beyak	1/20/2020 17:15	2/9/2020 15:16			21835
WO-3634	PM-3524	Ops & Fac - Fort Frances Muni Airport	Airport	Monthly Inspection-Airport	Visual Inspection	Completed	Mike Beyak	1/20/2020 17:14	2/9/2020 15:17			22678
WO-3608	PM-3520	Com Serv - Sister Kennedy	Sister Kennedy Centre	Preventative Maintenance-Sister Kennedy	HRV Filter Wash	Completed	Jim Garvie	12/20/2019 8:46	2/20/2020 8:56			22677
WO-3599	PM-3491	Ops & Fac - Fort Frances Muni Airport	Airport	Monthly Inspection-Airport	HRV Washable Pre-Filter Vacuum and Wash/ Furnace Filter Inspection	Completed	Mike Beyak	12/4/2019 16:04	2/9/2020 15:17			21848
WO-3598	PM-3490	Ops & Fac - Fort Frances Muni Airport	Airport	Monthly Inspection-Airport	HRV Washable Pre-Filter Vacuum and Wash/ Furnace Filter Inspection	Completed	Mike Beyak	12/4/2019 16:04	2/9/2020 15:17			21849
WO-3597	PM-3489	Ops & Fac - Fort Frances Muni Airport	Airport	Monthly Inspection-Airport	HRV Washable Pre-Filter Vacuum and Wash/ Furnace Filter Inspection	Completed	Mike Beyak	12/4/2019 16:04	2/9/2020 15:18			21846
WO-3596	PM-3488	Ops & Fac - Fort Frances Muni Airport	Airport	Monthly Inspection-Airport	HRV Washable Pre-Filter Vacuum and Wash/ Furnace Filter Inspection	Completed	Mike Beyak	12/4/2019 16:04	2/9/2020 15:18			21847
WO-3521	PM-3463	Ops & Fac - Public Works	Public Works	Preventative Maintenance	HRV Filter Change	Completed	Jim Garvie	11/12/2019 10:48	2/3/2020 11:04			22696
WO-3330	PM-3332	Ops & Fac - Public Works	Public Works	Preventative Maintenance	Hot Water Tank Inspection	Completed	Jim Garvie	8/6/2019 14:25	2/3/2020 9:14			22605