

Workorder Summary Report

Report Start Date: Jun 1, 2022 12:00 AM

Report End Date: Jun 30, 2022 11:59 PM

Location: 1103\*

Work Order Type: ADMIN,CALL,CAP,CORR,EMER,OPER,PM

Work Order Class:

				WorkOrder		PM Schedule		Workorder Details					
WO #	Asset ID	Asset Description	Location Description	Type	Class	FEQ	Units	Work Order Description	Status	Schedule Start	Actual Start	Actual Finsh	WorkLog Detail
<a href="#">2836501</a>			1103, Fort Frances WPCP, Facility, Safety Equipment	PM	Health and Safety	1	YEARS	Fire extinguishers annual inspections (1y)	COMP	6/1/22 12:00 AM	6/3/22 09:03 AM	6/3/22 09:03 AM	Fire extinguishers annual inspections (1y) - SPI did the annual fire extinguisher inspection/maintenance on May 26
<a href="#">2863350</a>			1103, Fort Frances WPCP	PM	Refurbish/ Replace/Repair	1	MONTHS	Diesel Gensets Inspection/ Functional Tests (1m) 1103	COMP	6/1/22 12:00 AM	6/30/22 03:09 PM	6/30/22 03:09 PM	
<a href="#">2863366</a>			1103, Fort Frances WPCP	PM	Health and Safety	1	YEARS	Fire Protection System Inspection (1y) 1103	COMP	6/1/22 12:00 AM	6/3/22 09:00 AM	6/3/22 09:00 AM	Fire Protection System Inspection (1y) 1103 - SPI did the annual fire extinguisher inspection/maintenance May 26
<a href="#">2863369</a>			1103, Fort Frances WPCP	PM	Health and Safety	1	MONTHS	Health And Safety Inspection (1m) 1103	COMP	6/1/22 12:00 AM	6/19/22 07:00 AM	6/19/22 08:00 AM	H&S Inspection - No issues.
<a href="#">2863704</a>			1103, Fort Frances WPCP	PM	Inspection	1	MONTHS	Blowers/Motors Inspection/Service (1m/3m) 1103	COMP	6/1/22 12:00 AM	6/19/22 12:30 PM	6/19/22 01:30 PM	Blower Maint. - I greased all blowers.
<a href="#">2863715</a>	0000246402	CENTRIFUGE GS2-2-1 TEACUP/ GRIT SNAIL	1103, Fort Frances WPCP, Process, Primary Treatment, Primary Sludge Degritting	PM	Inspection	1	MONTHS	Teacup Centrifuge Inspection/ Service (1m/3m/1y) 1103	COMP	6/1/22 12:00 AM	6/21/22 11:55 AM	6/21/22 12:55 PM	Teacup Maint. - I removed the lid to find little to no debris.
<a href="#">2863732</a>			1103, Fort Frances WPCP	PM	Refurbish/ Replace/Repair	3	MONTHS	Clarifiers Inspection/Service (3m) 1103	COMP	6/1/22 12:00 AM	6/26/22 01:09 PM	6/26/22 01:09 PM	
<a href="#">2867275</a>			Fort Frances Water Pollution Control Plant	CALL	Compliance	0		Announced plant Bypass event termination after hours	COMP		6/1/22 08:30 PM	6/1/22 09:30 PM	Announced plant Bypass event termination after hours - After discussing when our bypass termination would likely have to be announced by as well as how close we were to having the bypass start up again with Ty on June 1, we agreed that I would come back to the plant later in the evening to confirm that it was time to terminate.

Workorder Summary Report

Report Start Date: Jun 1, 2022 12:00 AM

Report End Date: Jun 30, 2022 11:59 PM

Location: 1103\*

Work Order Type: ADMIN,CALL,CAP,CORR,EMER,OPER,PM

Work Order Class:

				WorkOrder		PM Schedule		Workorder Details					
WO #	Asset ID	Asset Description	Location Description	Type	Class	FEQ	Units	Work Order Description	Status	Schedule Start	Actual Start	Actual Finsh	WorkLog Detail
<a href="#">2870629</a>			1103, Fort Frances WPCP, Process	CALL	Refurbish/ Replace/Repair	0		Plant power failure call in 1103 June 14, 2022	COMP		6/14/22 06:55 PM	6/14/22 10:50 PM	Plant power failure call in 1103 June 14, 2022 - Plant power failure call in 1854 hours. I drove to the plant and then reset the phase loss protection system and main plant power. After acknowledging all alarms on the SCADA computer I started equipment not yet running. Central Avenue lift station had all 3 pumps on at 1930 hours and level was climbing so I drove to the station where I was able to purge some air from pump 2. Pumping immediately improved and the level was under control quickly Reset pump 3 fault at Fifth St. lift station UV bypass Reference #1-1UEH0F began at 2105 hours. Called Julien at SAC 2110 hours, Brian at MOH 2123 hours, Craig TOFF 2125 hours, Geoff in Emo 2126 hours and our manager Ty at 2128 hours. Grabbed a sample of the UV bypass 2132 hours.
<a href="#">2873517</a>	0000246436	PANEL CONTROL PCL	1103, Boundary Pumping Station, Facility	CALL	Refurbish/ Replace/Repair	0		Boundary Road high level alarm call in 1103.	COMP		6/26/22 08:30 PM	6/26/22 10:00 PM	Boundary Road high level alarm call in 1103. - I was called by the auto dialer at 2030 hours for a Boundary Road lift station high level alarm. I drove to the plant and called CommunicAction. I was able to acknowledge the alarms on the SCADA computer. There were several other Boundary Road alarms that had come in at the same time that were acknowledged as well. This indicates to me that a PLC error had occurred but was fine now.

Workorder Summary Report

Report Start Date: Jun 1, 2022 12:00 AM

Report End Date: Jun 30, 2022 11:59 PM

Location: 1103\*

Work Order Type: ADMIN,CALL,CAP,CORR,EMER,OPER,PM

Work Order Class:

				WorkOrder		PM Schedule		Workorder Details					
WO #	Asset ID	Asset Description	Location Description	Type	Class	FEQ	Units	Work Order Description	Status	Schedule Start	Actual Start	Actual Finsh	WorkLog Detail
<a href="#">2874368</a>	0000246422	METER LEVEL MULTIRANGER PLUS	1103, Church Pumping Station, Process	CALL	Refurbish/ Replace/Repair	0		Church Street high level alarm call in 1103	COMP		6/27/22 06:35 PM	6/27/22 10:00 PM	Church Street high level call in 1103 June 27/22 - I was called by the auto dialer at1836 hours for a Church Street lift station high level alarm. I called CommunicAction and drove to the plant. I acknowledged the alarms on the SCADA computer and then drove to the station where both pumps were operating correctly but level was high. I then drove to the White Pine lift station where I found that the wet well was high and there were multiple alarms on the Atlas pump HMI. I started one of the lift station pumps and then acknowledged the Atlas pump alarms and was able to run it. I called Craig Miller to discuss the situation and I will let him know how everything is running once the levels are normal. Levels at Church Street and White Pine lift stations are normal and pump 1 at White Pine lift station is keeping up fine. I notified Craig miller that the Atlas pump is currently off and we will run pump 1 at White Pine lift station overnight. Craig will have a town crew address the Atlas pump issues in the morning.