

Workorder Summary Report

Report Start Date: Mar 1, 2021 12:00 AM  
Report End Date: Mar 31, 2021 11:59 PM  
Location: 1103\*  
Work Order Type: ADMIN,CALL,CAP,CORR,EMER,OPER,PM  
Work Order Class:

				WorkOrder		PM Schedule		Workorder Details					
WO #	Asset ID	Asset Description	Location Description	Type	Class	FEQ	Units	Work Order Description	Status	Schedule Start	Actual Start	Actual Finsh	WorkLog Detail
<a href="#">2174872</a>	0000227360	MOTOR PUMP DIGESTER SLUDGE #1	1103, Fort Frances WPCP, Process, Sludge Treatment & Handling, Sludge Digestion	CALL	Refurbish/ Replace/Repair	0		Digester heater failure 1103	COMP		3/12/21 02:39 AM	3/12/21 02:43 AM	Digester Low Temp Alarm -I arrived onsite to find that the heater had failed in the small doghouse so I replaced it with a new heater and monitored .
<a href="#">2178232</a>	0000227360	MOTOR PUMP DIGESTER SLUDGE #1	1103, Fort Frances WPCP, Process, Sludge Treatment & Handling, Sludge Digestion	CALL	Refurbish/ Replace/Repair	0		Digester Heater Failure 1103	COMP		3/31/21 08:55 AM	3/31/21 09:00 AM	Digester Heater Failure -I found the wall heater to have failed so I replaced the portable heater with a new one and will call an electrician to repair or replace wall unit.
<a href="#">2169592</a>	0000227376	PANEL ALARM/ DIALER	1103, Fort Frances WPCP, Process, Process Control & Monitoring	PM	Inspection	1	MONTHS	Critical Alarm/Dialer Testing (1m) 1103	COMP	3/1/21 12:00 AM	3/27/21 11:00 AM	3/27/21 12:00 PM	Monthly Dialer -We test daily.
<a href="#">2169596</a>			1103, Fort Frances WPCP	PM	Refurbish/ Replace/Repair	1	MONTHS	Diesel Gensets Inspection/ Functional Tests (1m) 1103	COMP	3/1/21 12:00 AM	3/1/21 09:15 AM	3/1/21 11:15 AM	Monthly Genset -Ran all gensets 1 hour under load.
<a href="#">2169612</a>			1103, Fort Frances WPCP	PM	Health and Safety	1	MONTHS	Health And Safety Inspection (1m) 1103	COMP	3/1/21 12:00 AM	3/28/21 07:30 AM	3/28/21 08:30 AM	Monthly H&S -No issues .
<a href="#">2169623</a>			1103, Fort Frances WPCP	PM	Inspection	1	MONTHS	TPM Inspection/Maintenance (1m) 1103	COMP	3/1/21 12:00 AM	4/5/21 07:19 AM	4/5/21 07:19 AM	
<a href="#">2169968</a>			1103, Fort Frances WPCP	PM	Inspection	1	MONTHS	Blowers/Motors Inspection/Service (1m/3m) 1103	COMP	3/1/21 12:00 AM	3/27/21 09:00 AM	3/27/21 10:00 AM	Blower Maint. -I greased blowers 5,4 and 2
<a href="#">2169978</a>	0000246402	CENTRIFUGE GS2-2-1 TEACUP/ GRIT SNAIL	1103, Fort Frances WPCP, Process, Primary Treatment, Primary Sludge Degritting	PM	Inspection	1	MONTHS	Teacup Centrifuge Inspection/ Service (1m/3m/1y) 1103	COMP	3/1/21 12:00 AM	3/24/21 02:14 PM	3/24/21 02:14 PM	Teacup Centrifuge Inspection/ Service (1m/3m/1y) 1103 -Drained and inspected teacup, no debris. Lubricated chain and greased bearings on snail. Drained and hosed snail and brought back on line. KC
<a href="#">2169995</a>			1103, Fort Frances WPCP	PM	Refurbish/ Replace/Repair	3	MONTHS	Clarifiers Inspection/Service (3m) 1103	COMP	3/1/21 12:00 AM	4/5/21 07:33 AM	4/5/21 07:33 AM	Clarifiers Inspection/Service (3m) 1103 -Greased both clarifier drives. Running smooth and quiet. KC