

Workorder Summary Report

Report Start Date: Nov 1, 2017 12:00 AM

Report End Date: Nov 30, 2017 11:59 PM

Location: 1103\*

Work Order Type: All Workorder Type

Work Order Class:

				WorkOrder		PM Schedule		Workorder Details					
WO #	Asset ID	Asset Description	Location Description	Type	Class	FEQ	Units	Work Order Description	Status	Schedule Start	Actual Start	Actual Finsh	WorkLog Detail
<a href="#">536065</a>			1103, Fort Frances WPCP	PM	HEALTH AND SAFETY	1	MONTHS	Health And Safety Inspection (1m) 1103	COMP	11/1/17 12:00 AM	11/30/17 01:00 PM	11/30/17 02:00 PM	Monthly H&S -Still some outstanding construction related issues and I noticed a 6 foot step ladder that had some bent braces that I removed from service and we will need to replace.
<a href="#">536075</a>			1103, Fort Frances WPCP	PM	INSPECTION	1	MONTHS	TPM Inspection/Maintenance (1m) 1103	COMP	11/1/17 12:00 AM	12/4/17 07:05 AM	12/4/17 07:05 AM	
<a href="#">536464</a>			1103, Fort Frances WPCP	PM	INSPECTION	1	MONTHS	Blowers/Motors Inspection/Service (1m/3m) 1103	COMP	11/1/17 12:00 AM	11/25/17 10:00 AM	11/25/17 12:00 PM	Blower Maint. -I changed oil in blowers 4 & 5 as well as greased all blowers and I changed air filters in 4 & 5.
<a href="#">536045</a>	0000227376	PANEL ALARM/DIALER	1103, Fort Frances WPCP, Process, Process Control & Monitoring	PM	INSPECTION	1	MONTHS	Critical Alarm/Dialer Testing (1m) 1103	COMP	11/1/17 12:00 AM	11/29/17 10:00 AM	11/29/17 11:00 AM	Tested -We test daily and Lakeside controls also tested the dialer during programming changes for new construction.
<a href="#">536472</a>	0000246402	CENTRIFUGE GS2-2-1 TEACUP/GRIT SNAIL	1103, Fort Frances WPCP, Process, Primary Treatment, Primary Sludge Degritting	PM	INSPECTION	1	MONTHS	Teacup Centrifuge Inspection/Service (1m/3m/1y) 1103	COMP	11/1/17 12:00 AM	11/28/17 01:00 PM	11/28/17 02:00 PM	Teacup Maint. -I inspected and hosed off the snail.
<a href="#">536049</a>			1103, Fort Frances WPCP	PM	REFURBISH/REPLACE/REPAIR	1	MONTHS	Diesel Gensets Inspection/Functional Tests (1m) 1103	COMP	11/1/17 12:00 AM	11/28/17 10:00 AM	11/28/17 03:00 PM	Monthly Genset Run And Service -Gensets were all ran and serviced by Wajax Thunder Bay as part of the towns service of all gensets.
<a href="#">536965</a>			1103, Fort Frances WPCP	PM	REFURBISH/REPLACE/REPAIR	1	YEARS	Tank Inspections (1y) 1103	COMP	11/1/17 12:00 AM	12/4/17 07:07 AM	12/4/17 07:07 AM	