



Ontario Clean Water Agency
Agence Ontarienne Des Eaux

Fort Frances WPCP
200 McIrvine Rd
Fort Frances, Ontario
P9A 3S3
Tel: 807-274-3121
Fax: 807-274-8381

November 12, 2015

Town of Fort Frances
320 Portage Avenue
Fort Frances Ontario
P9A 3M5

Attention: Mr. Doug Herr
Environmental and Facilities Superintendent

Dear Doug:

**Re: Fort Frances Wastewater Treatment Facility
October 2015 Monthly Report**

As per the operating agreement, the attached document is the October 2015 monthly report for the Fort Frances Wastewater Treatment Facility.

The report highlights the influent and effluent quality and the process parameters. Additionally, the routine operation and maintenance activities conducted by the operators are summarized.

If you have any questions regarding this report do not hesitate to contact Mr. Larry Wachter – Operations Manager.

Yours truly,

A handwritten signature in black ink, appearing to read "Kelly Cunningham".

Kelly Cunningham
Senior Operator

For Larry Wachter
Operations Manager

**The Corporation of the Town of Fort Frances
Wastewater Treatment Plant
(Sewage Plant)
October 2015 Monthly Operations Report**

INTRODUCTION

In accordance with the Agreement between the Ontario Clean Water Agency (Operating Authority) and the Town of Fort Frances, the Fort Frances Sewage Treatment Plant is required to prepare a monthly report. This document covers the reporting month of October 2015; the facility performance report summarizes important information regarding the quality of the effluent, wastewater, analytical test results, maintenance operations, and relevant activities of the WWTP.

DESCRIPTION OF WORKS

Capacity of Works	9000 m ³ /day (average flow)
Service Area	Town of Fort Frances and Couchiching Reserve
Service Population	9000
Effluent Receiver	Rainy River
Major Process	Secondary treatment facility complete with a phosphorus removal system; ultra violet disinfection; aerobic sludge stabilization and dewatering

The Fort Frances Sewage Treatment Plant received and operates its operation under *Certificate of Approval Number 3-0049-96-006*, in accordance with Section 53 of the Ontario Water Resources Act. The Certificate of Approval outlines the terms and conditions and the report captures these terms and conditions in the following sections.

LABORATORY

ALS Laboratory Group – Thunder Bay is contracted to conduct the required analytical tests of the influent (raw) and effluent samples; weekly requirement.

OCTOBER 2015 EFFLUENT QUALITY

<i>Parameters</i>	<i>Monthly Actual Concentration mg/L</i>	<i>Compliance Criteria Concentration mg/L</i>	<i>Performance Objective Concentration mg/L</i>	<i>Monthly Actual Loading, kg/d</i>	<i>Compliance Criteria Loading kg/d</i>	<i>Performance Objective Loading kg/d</i>
CBOD ₅	2.2 mg/L	25 mg/L	15 mg/L	10.8 kg/d	225 kg/d	135 kg/d
Suspended Solids	6.0 mg/L	25 mg/L	15 mg/L	34.5 kg/d	225 kg/d	135 kg/d
Total Phosphorus	0.21 mg/L	1.0 mg/L	1.0 mg/L	1.1 kg/d	9 kg/d	9 kg/d
Ammonia as N	0.09 mg/L					
Nitrite as N	0.05 mg/L					
Nitrate as N	5.47 mg/L					
Total Cl ₂ Residual		<0.01 mg/L (when in use)				
E-Coli		9.9 count/100 ml (geometric mean)		200 count/100ml (geometric mean)	E-coli not to exceed 150 organisms/100ml (monthly geometric mean density)	
pH			pH range 7.5 to 7.8; average pH was 7.7			
Temperature degrees C			Temperatures ranged from 14.5 – 17.0 average temperature of effluent at 15.9			

Compliance criteria are mandatory requirements of the C of A and performance objectives are a goal to be achieved using best reasonable efforts.

WASTEWATER LIQUID PROCESS

The average daily flow for October was 5155.1 m³/day. This represents 57% of the design average flow. Total treated flow for the month was 159808 m³.

The Fort Frances WWTP met all effluent compliance criteria for the parameters listed above. As expected, process took some time to recover from the nine hour power outage in September.

INVENTORY

Chemical	End of Month Status	Units
Hypochlorite	950 +/- @ 7.0% + 615 @ 12%	Litres
Alum	4.5 +/- @ 60 %	Cubic meters
Polymer	24 Bags (800 kg)	Bags (25 kg/bag)

MAINTENANCE

The operators performed the routine operations and maintenance at the treatment plant and pumping stations. The activities are highlighted as follows:

Treatment Plant:

- Alternated lead/lag pumps
- Adjusted fluidizing water to head cell and grit snail as needed
- Greased GBT, mechanical bar screen and grit snail. Lubricated drive chain on grit snail and bar screen
- Regular cleaning of head works EW basket strainer
- Installed a new set of brushes in the polymer mixer motor
- Regular cleaning of seal water strainer TFP 9-5
- Hot water flushed alum lines
- Cleaned polymer lines
- Greased all blowers
- Acid washed sleeves UV banks 1 and 2
- New longitudinal drive installed for clarifier 2
- Repaired alum line at aeration cells
- Replaced the belt and filters ASU 101 and greased bearings

Pump Stations:

- Ran gensets
- Changed seal water strainers
- Cleaned bar screens

OPERATIONAL ISSUES

There was 1 day in the month where effluent TSS exceeded 25 mg/L but the monthly average met the C of A compliance criteria.

SLUDGE SUMMARY

The volume directed to the gravity belt thickener totaled 500.6 m³ for the month. Asselin Transportation and Storage Limited hauled a total of 119.6 m³ of thickened digested sludge (average 12.0m³/load) to the Town of Fort Frances landfill site.

COMPLAINTS

There were no complaints during the report period.

BY-PASS REPORT(S)

There were no bypass events in the report period.

COMMENTS

Plant power consumption for the month was 699 (x 180 multiplier) kWh.
One effluent TSS result for the Wastewater Systems Effluent Regulations was missed in October and this omission has been reported.

REPORTS

ALS – Environmental Analytical Reports (on-file at plant)
Fort Frances WPCP Equipment Run Time Report (on-file at plant)
Bypass Report (on-file at plant as per occurrence)

Month	Sewage Flows Year 2015					Usage % Plant Capacity	Sludge Volume Hauled M3	Removal Efficiency	
	Avg. Day Flow m3	Max Day Flow m3	Total Treated Volume ML	Total ByPass Volume ML	Total Volume ML			CBOD5	0.958429876
January	5205.2	5615	161362		161362	58%	133.6	Total Phosphorus	0.89375
February	5008.5	5247	140237		140237	56%	163.2		
March	5608.6	6833	173865		173865	62%	244.8		
April	5628.8	5970	168865		168865	63%	239.8		
May	7834.5	15983	242869		242869	87%	240.3		
June	7292.4	10570	218773		218773	81%	217.4		
July	5805.5	6247	179969		179969	65%	242.8		
August	5920.3	6606	183529		183529	66%	217.3		
September	5437.1	5822	163113		163113	60%	239.6		
October	5155.1	6109	159808		159808	57%	119.6		
November						0%			
December						0%			
Sum				0	1792390		2058.4		
Average	5890		179239		179239	65%	205.8		
Max		15983	242869		242869				
C of A	9000	18000							

Month	CBOD5				Suspended Solids				Total Phosphorus				E. Coli		pH	
	Avg Raw CBOD (mg/L)	Avg. Eff. CBOD (mg/L)	Avg. Load CBOD (kg/day)	Avg Raw S.S. (mg/L)	Avg. Eff. S.S. (mg/L)	Avg. Load S.S. (kg/day)	Avg Raw T.P. (mg/L)	Avg. Eff. T.P. (mg/L)	Avg. Load T.P. (kg/day)	Geo Mean Counts /100ml	Monthly Minimum	Monthly Maximum				
January	84.5	2.6	13.6	151.9	6.0	31.0	2.5	0.23	1.18	17.8	6.8	7.6				
February	87.0	3.1	15.3	136.4	6.4	32.1	2.2	0.22	1.12	8.3	6.9	7.5				
March	62.8	3.5	19.6	127.6	8.0	45.1	1.9	0.23	1.29	14.8	6.8	7.5				
April	66.3	4.4	24.7	135.3	7.8	44.2	1.9	0.28	1.57	56.6	6.8	7.2				
May	48.5	3.6	34.9	109.6	5.4	43.4	1.4	0.18	1.40	20.1	6.8	7.3				
June	51.2	2.7	19.8	115.8	4.2	31.7	1.3	0.17	1.30	8.3	7.0	7.5				
July	74.8	2.1	12.4	133.1	3.5	20.6	2.1	0.22	1.30	5.8	7.1	7.7				
August	82.8	2.2	13.1	147.3	6.8	40.6	2.7	0.22	1.30	13.3	7.3	7.9				
September	76.0	4.1	22.2	157.6	10.5	56.6	2.3	0.25	1.34	76.4	7.4	7.8				
October	99.8	2.2	10.8	156.9	6.6	34.5	2.5	0.21	1.08	9.9	7.5	7.8				
November																
December																
Average	73.4	3.1	18.6	137.2	6.5	38.0	2.1	0.22	1.29	23.1	7.0	7.6				
Max	99.8	4.4	34.9	157.6	10.5	56.6	2.7	0.28	1.57	76.4	7.5	7.9				
C of A		25	225		25	225		1	9	200	6.0	9.5				