

Workorder Summary Report

Report Start Date: Nov 1, 2020 12:00 AM

Report End Date: Nov 30, 2020 11:59 PM

Location: 1103\*

Work Order Type: ADMIN,CALL,CAP,CORR,EMER,OPER,PM

Work Order Class:

				WorkOrder		PM Schedule		Workorder Details					
WO #	Asset ID	Asset Description	Location Description	Type	Class	FEQ	Units	Work Order Description	Status	Schedule Start	Actual Start	Actual Finsh	WorkLog Detail
<a href="#">1994450</a>	0000227376	PANEL ALARM/ DIALER	1103, Fort Frances WPCP, Process, Process Control & Monitoring	PM	Inspection	1	MONTHS	Critical Alarm/Dialer Testing (1m) 1103	COMP	11/2/20 12:00 AM	11/22/20 11:00 AM	11/22/20 12:00 PM	Dialer Test -We test daily.
<a href="#">1994454</a>			1103, Fort Frances WPCP	PM	Refurbish/ Replace/Repair	1	MONTHS	Diesel Gensets Inspection/ Functional Tests (1m) 1103	COMP	11/2/20 12:00 AM	11/23/20 09:30 AM	11/23/20 11:30 AM	Monthly Gensets -I ran all gensets 1 hour under load.
<a href="#">1994470</a>			1103, Fort Frances WPCP	PM	Health and Safety	1	MONTHS	Health And Safety Inspection (1m) 1103	COMP	11/2/20 12:00 AM	11/21/20 08:00 AM	11/21/20 09:00 AM	Monthly H&S -No issues this month.DH
<a href="#">1994481</a>			1103, Fort Frances WPCP	PM	Inspection	1	MONTHS	TPM Inspection/Maintenance (1m) 1103	COMP	11/2/20 12:00 AM	12/2/20 01:00 PM	12/2/20 01:00 PM	
<a href="#">1994795</a>			1103, Fort Frances WPCP	PM	Inspection	1	MONTHS	Blowers/Motors Inspection/Service (1m/3m) 1103	COMP	11/2/20 12:00 AM	11/22/20 09:30 AM	11/22/20 10:30 AM	Monthly Blowers -I greased all blowers.DH
<a href="#">1994803</a>	0000246402	CENTRIFUGE GS2-2-1 TEACUP/ GRIT SNAIL	1103, Fort Frances WPCP, Process, Primary Treatment, Primary Sludge Degritting	PM	Inspection	1	MONTHS	Teacup Centrifuge Inspection/ Service (1m/3m/1y) 1103	COMP	11/2/20 12:00 AM	12/2/20 12:40 PM	12/2/20 12:40 PM	Teacup Centrifuge Inspection/ Service (1m/3m/1y) 1103 -Drained and inspected Teacup and there was no debris. Drained and hosed Snail, greased bearings and lubricated drive chain. Kelly C.
<a href="#">1998820</a>	0000227360	MOTOR PUMP DIGESTER SLUDGE #1	1103, Fort Frances WPCP, Process, Sludge Treatment & Handling, Sludge Digestion	PM	Refurbish/ Replace/Repair	0		Digester Low Temp Alarm 1103	COMP		11/10/20 02:51 PM	11/10/20 02:56 PM	Digester Low Temp Alarm -I arrived onsite to find the portable heater had failed so I replaced it with a new heater and also adjusted permanent heaters .
<a href="#">1999007</a>	0000246437	METER LEVEL MULTIRANGER PLUS	1103, Boundary Pumping Station, Process	CALL	Refurbish/ Replace/Repair	0		Boundary Road Lift Station High Level Alarm 1103	COMP		11/12/20 08:10 PM	11/12/20 09:15 PM	
<a href="#">2000793</a>	0000129822	BOILER NATURAL GAS 1	1103, Fort Frances WPCP, Facility, Heating Ventilation Air Conditioning, Boiler	CALL	Refurbish/ Replace/Repair	0		Hot Water System 1103	BUSCOMP		11/24/20 07:54 AM	11/24/20 07:59 AM	