

Month	Sewage Flows Year 2016					Usage	Sludge	Sludge	Removal Efficiency	
	Avg. Day	Max Day	Total	Total	Total	% Plant	Volume	Bins	CBOD5 0.967475951	
	Flow	Flow	Treated	ByPass	Volume	Capacity	Hauled	Hauled	Suspended Solids 0.963222417	
	m3	m3	Volume ML	Volume ML	ML		M3		Total Phosphorus 0.922590837	
January	5636.9	6162	174745		174745	63%	85.3	11		
February	6284.1	9818	175956		175956	70%	63.3	8		
March	7199.5	8844	223183		223183	80%	85.4	12		
April						0%				
May						0%				
June						0%				
July						0%				
August						0%				
September						0%				
October						0%				
November						0%				
December						0%				
Sum				0	573884		234	31		
Average	6374		191295		191295	71%	78.0	10.33333333		
Max		9818	223183		223183			12		
C of A	9000	18000								

	BOD5/CBOD5			Suspended Solids			Total Phosphorus			Nitrogen		E. Coli
	Avg. Raw	Avg. Eff.	Avg. Load	Avg. Raw	Avg. Eff.	Avg. Load	Avg. Raw	Avg. Eff.	Avg. Load	Avg. Raw	Avg. Eff.	Geo Mean
Month	BOD	CBOD	CBOD	S.S	S.S	S.S	T.P	T.P	T.P	TKN	Total N	Counts
	(mg/L)	(mg/L)	(kg/day)	(mg/L)	(mg/L)	(kg/day)	(mg/L)	(mg/L)	(kg/day)	(mg/L)	(mg/L)	/100ml
January	84.0	2.0	11.3	138.4	3.2	18.1	2.31	0.11	0.63	17.5	8.8	3.6
February	64.3	2.3	15.5	142.6	5.8	35.2	2.04	0.18	1.09	16.5	8.0	11.8
March	70.0	2.8	20.5	118.7	5.7	42.0	1.98	0.20	1.42	15.8	8.0	39.5
April												
May												
June												
July												
August												
September												
October												
November												
December												
Average	72.8	2.4	15.8	133.2	4.9	31.8	2.1	0.16	1.05	16.6	8.3	18.3
Max	84	2.8	20.5	142.6	5.8	42	2.3	0.20	1.42	17.5	8.8	39.5
C of A		25	225		25	225		1.0	9.0	200	6.0	200