

September 8, 2020

Report To: Mayor and Council

From: Aaron Bisson, Manager of Recreation and Culture

RE: Museum Fire Alarm

The Museum has a rate of rise device that has been malfunctioning over the last while. We have had a few different contractors look at the unit but due to the age of the system and the company that was used during that install we are not able to replace that device. The entire fire alarm system would need to be replaced in this museum to fix this issue.

There is a second device in the general area so we do not have an immediate concern but should look at replacing the fire alarm system at the Museum for the 2021 budget year. Preliminary estimates to have the system replaced been estimated at around \$5,000.00.

Respectfully Submitted,

A handwritten signature in black ink, appearing to read 'A. Bisson', with a long horizontal stroke extending to the right.

Aaron Bisson
Manager of Recreation and Culture