

TOWN OF FORT FRANCES
Operations and Facilities Division - Environmental Area - Operations Statistics
January-20

STAFFING:

See Operations Statistics prepared by M. Strachan, Superintendent of Transportation

OVERTIME HOURS - Equivalent Straight Time Hours

See Operations Statistics prepared by M. Strachan, Superintendent of Transportation

WATER DISTRIBUTION & WASTE WATER COLLECTION:

See Monthly Summary (Attached)
Repaired main break behind Rainy Lake Sports & Harbourage in back lane
Repaired collapsed sewer service on 700 block of Church St.
P. LeMesurier in Dryden for 3 days of training
J. Nicolay completed Wastewater Collection 1 training and exam in Dryden
B. Patterson received Water Distribution 1 and Wastewater Collection 1 licenses

WATER TREATMENT PLANT:

January 2019 - In receipt of the Water Treatment Plant Monthly Report
J. Bruyere cross-training @ WTP.
G. Wiedenhoef in Dryden for 3 days of training
MECP visited for annual inspection (announced) - Jan 16 / 17

WASTE-WATER TREATMENT FACILITY:

January 2019 - In receipt of the Wastewater Treatment Facility Monthly Report.
Repaired overhead door to garage at main shop

WASTE MANAGEMENT:

Garbage Collection:

Garbage not picked up - 33 houses

Sanitary Landfill (Waste Disposal Site):

Landfill Scales periodically not functioning during this period. During thaws and freeze / thaw causing the electronics to behave erratically. Also snow and ice build up around the scale plates not allowing them to float freely. Avery-Weightronix has been servicing, as required.

Amount of residential waste (kg) delivered to the landfill:
155,550

Amount of ICI waste (kg) delivered to the landfill:
264,880

Recycling:

Recycle not picked up - 32 houses

Amount of recycled waste (Metric Tonnes) diverted from the landfill:
43.70 (Emterra)

Prepared By: Craig Miller, P.Eng. Environmental Superintendent

Date: 20-Apr-20

TOWN OF FORT FRANCES
Operations and Facilities Division - Environmental Area - Operations Statistics
February-20

STAFFING:

See Operations Statistics prepared by M. Strachan, Superintendent of Transportation

OVERTIME HOURS - Equivalent Straight Time Hours

See Operations Statistics prepared by M. Strachan, Superintendent of Transportation

WATER DISTRIBUTION & WASTE WATER COLLECTION:

See Monthly Summary (Attached)

All operators attended 3 days of training at Nanicost for CEU Feb 18-Feb 20 (by Keewaytinook Centre of Excellence)

J. Nicolay received Water Distribution Class 1 certificate upgrade from OIT

P. LeMesurier renewed Water Distribution Class 2 certificate for 3 years

Re-charged water main Feb 25 along Sinclair between Victoria & Portage so Riversedge could have water at Portage Stores.

Turned water on for UNFC Daycare on McIrvine Road (for construction purposes)

WATER TREATMENT PLANT:

February 2020 - In receipt of the Water Treatment Plant Monthly Report

All operators attended 3 days of training at Nanicost for CEU Feb 18-Feb 20 (by Keewaytinook Centre of Excellence)

G. Wiedenhoef and P. LeMesurier had been scheduled for Water Treatment 3 training in Dryden but cancelled by KCE

J. Bruyere cross - training at WTP

WASTE-WATER TREATMENT FACILITY:

February 2020 - In receipt of the Wastewater Treatment Facility Monthly Report.

WASTE MANAGEMENT:

Issued RFP for Landfill Expansion - closing April 21.

Garbage Collection:

Garbage not picked up - 22 houses

Sanitary Landfill (Waste Disposal Site):

Landfill Scales periodically not functioning during this period. During thaws and freeze / thaw causing the electronics to behave erratically. Also snow and ice build up around the scale plates not allowing them to float freely. Avery-Weightronix has been servicing, as required.

Amount of residential waste (kg) delivered to the landfill:

127,990

Amount of ICI waste (kg) delivered to the landfill:

238,460

Recycling:

Recycle not picked up - 35 houses

Amount of recycled waste (Metric Tonnes) diverted from the landfill:

39.96 (Emterra)

Prepared By: Craig Miller, P.Eng. Environmental Superintendent

Date: 20-Apr-20

TOWN OF FORT FRANCES
Operations and Facilities Division - Environmental Area - Operations Statistics
March-20

STAFFING:

See Operations Statistics prepared by M. Strachan, Superintendent of Transportation

OVERTIME HOURS - Equivalent Straight Time Hours

See Operations Statistics prepared by M. Strachan, Superintendent of Transportation

WATER DISTRIBUTION & WASTE WATER COLLECTION:

See Monthly Summary (Attached)

Repaired water main break at intersection of 6th and Armit.

Repaired water service at 838 Armit Ave

All training cancelled due to COVID-19 Pandemic. Staff separated to protect operation.

WATER TREATMENT PLANT:

March 2020 - In receipt of the Water Treatment Plant Monthly Report

Reviewed and updated all elements 1-7 of DWQMS

J. Bruyere cross - training at WTP

All training cancelled due to COVID-19 Pandemic. Staff separated to protect operation.

WASTE-WATER TREATMENT FACILITY:

March 2020 - In receipt of the Wastewater Treatment Facility Monthly Report.

In receipt of Annual WWTP report by OCWA

WASTE MANAGEMENT:

Garbage Collection:

Garbage not picked up - 20 houses

Sanitary Landfill (Waste Disposal Site):

Landfill Scales periodically not functioning during this period. During thaws and freeze / thaw causing the electronics to behave erratically. Also snow and ice build up around the scale plates not allowing them to float freely. Avery-Weightronix has been servicing, as required.

Amount of residential waste (kg) delivered to the landfill:

192,660

Amount of ICI waste (kg) delivered to the landfill:

243,746

Recycling:

Recycle not picked up - 25 houses

Amount of recycled waste (Metric Tonnes) diverted from the landfill:

27.75 (Emterra)

Prepared By: Craig Miller, P.Eng.

Environmental Superintendent

Date: 20-Apr-20

Water Works		Years			
DATE	WORK	2018	2019	2020	
Jan	THAW FROZEN WL	1	6	1	
	TURN WATER OFF	1	6		
	TURN WATER OFF/ON	4	5		
	TURN WATER ON	5			
Jan Total		11	17	1	
Feb	THAW FROZEN WL	27	11		
	TURN WATER OFF	3	3	1	
	TURN WATER OFF/ON		5	1	
	TURN WATER ON	3		5	
Feb Total		33	19	7	
Mar	THAW FROZEN WL	3	27		
	TURN WATER OFF		2		
	TURN WATER OFF/ON	3	3	1	
	TURN WATER ON	12	7	1	
Mar Total		18	39	2	
Grand Total		62	75	10	

Sewer Works		Years			
DATE	WORK	2018	2019	2020	
Jan	CCTV SEWER SERVICE	1	1	3	
	UNPLUG SANITARY SEWER	20	21	7	
Jan Total		21	22	10	
Feb	CCTV SEWER SERVICE	2	2	1	
	THAW FROZEN SEWER	1			
	UNPLUG SANITARY SEWER	20	10	6	
Feb Total		23	12	7	
Mar	CCTV SEWER SERVICE	1	1		
	CONNECTION INSPECTION		1		
	UNPLUG SANITARY SEWER	12	9	3	
Mar Total		13	11	3	
Grand Total		57	45	20	

System Repairs		Years			
DATE	TYPE	2018	2019	2020	
Jan	CURBSTOP		1		
	SEWER SERVICE			2	
	WATERMAIN	1	1		
Jan Total		1	2	2	
Feb	CLEANOUT		2		
	CURBSTOP		8		
	SEWER SERVICE	1	1		
	WATER SERVICE		2		
Feb Total			13		
Mar	CLEANOUT		2		
	CURBSTOP		2		
	WATER SERVICE	2		1	
	WATERMAIN			1	
	SAN MANHOLE			1	
Mar Total		2	4	3	
Grand Total		3	19	5	