

TOWN OF FORT FRANCES
Operations and Facilities Division - Environmental Area - Operations Statistics
(August 2015)

STAFFING:

See Operations Statistics (August) 2015 prepared by M. Strachan, Superintendent of Transportation

OVERTIME HOURS - Equivalent Straight Time Hours

See Operations Statistics (August) 2015 prepared by M. Strachan, Superintendent of Transportation

WATER DISTRIBUTION:

Water Main Breaks:

- Number of water main breaks: None

Hydrant Repairs:

- Number of hydrant repairs: Five (5)
 - 104 Sixth St. W. (HYD093), Sixth St. W. at Wright Ave. (HYD062), 1020 York Ave. N. (HYD067) and Walker Ave. at Eight St. W. (HYD096) and Hudson Dr. at Walker Ave. (HYD098)

Hydrant Replacements:

- Number of hydrant replacements: None

Hydrant Installations (NEW):

- Number of new hydrant installations: None

Main Valve Repairs:

- Number of water main valve repairs: Two (2)
 - Sixth St. W. at McInvine Rd. (VAL054) and Hudson Dr. at Walker Ave. (VAL193)

Water Service Breaks:

- Number of water service breaks: None

Water Service Repairs:

- Number of water service repairs: Six (6)
 - Point Park RV Site, 320 Portage Ave., 363 Church St., 608 Crowe Ave., 521 Lillie Ave. and 700 Armit Ave.

Water Service Installations (NEW):

- Number of water service installations: None

Water Service Replacements:

- Number of water service replacements: One (1)
 - 1316 Sixth St. E.

Water Service Terminations:

- Number of water service terminations: One (1)
 - 501 Sixth St. W.

Water Service Turn "Off/On":

- Number of water service turn "Off/On": Nineteen (19)
 - 839 Christie Ave., 559 Elm Ave., 1030 Second St. E. (2), 363 Church St., 608 Crowe Ave. (2),
 - 103 Sixth St. E. (3), 521 Lillie Ave. (2), 812 Portage Ave. (2), 230 Third St. W., 903 Williams Ave. (2)
 - and 1014 Colonization Rd. W. (2)

Frozen Water Services:

- Number of frozen water services: None

Water Meter Installations/Replacements:

- Number of water meter installations/replacements: None

Backflow Preventer Installations/Replacements:

- Number of backflow preventer installations/replacements: None

Other Information:

- Summarized final costs for invoicing associated with private works
- Recorded locations of curb stops at various locations.
- Continued with locates (as required) of the Town's infrastructure for various Contractors/Utility Companies.
- Continued with the valve exercising program (Area 1)
- Worked in conjunction with T. Veert Contracting and Bay City disinfecting and water quality testing before putting the new water main, service lines and hydrants into service.
- August 14 & 17, 2015 - Assisted Couchiching F. N. in the repair of fire hydrant valve.

WATER TREATMENT PLANT:

- August, 2015 - In receipt of the Water Treatment Plant Monthly Report

SEWERAGE COLLECTION:

Wastewater Main Backups:

- Number of wastewater main backup: None

Wastewater Main Repairs:

- Number of wastewater main repairs: None

Wastewater Manhole Repairs:

- Number of wastewater manhole repairs: One (1)
 - Victoria Ave. - 100 blk.

Sewer Service Breaks:

- Number of sewer service breaks: None

Sewer Service Repairs:

- Number of sewer service repairs: Three (3)
 - 916 Frenette Ave., 1205 Colonization Rd. W. and 410 Sinclair St.

Sewer Service Installations (NEW):

- Number of sewer service installations: None

Sewer Service Terminations:

- Number of sewer service terminations: None

Sewer Service Replacements:

- Number of sewer service replacement: None

Other Information:

- Cleaned Nine (9) plugged sewer services at the following locations:
 - 561 Elm Ave., 303 Sixth St. W., 822 Crowe Ave., 1006 First St. E., 911 Victoria Ave. N.,
 - 907 Victoria Ave. N., 929 Third St. E., 220 Scott St. and 424 King's Hwy.
- August 12, 2015 - Assisted Seine River F. N. in the cleaning of their sanitary sewer mains.
- CCTV inspected various building sewer services.
- Recorded locations of cleanouts at various locations.

WASTE-WATER TREATMENT FACILITY:

- August, 2015 - In receipt of the Wastewater Treatment Facility Monthly Report.

WASTE MANAGEMENT:

Garbage Collection:

- Number of complaints regarding garbage collection:
 - Town - 0 complaints, Asselin's - 1 complaint

Sanitary Landfill (Waste Disposal Site):

Landfill Scales functioning properly during this period.

- Amount of residential waste delivered to the landfill:
 - 273,250 kgs (273.25 tonnes)
- Amount of ICI waste delivered to the landfill:
 - 357,180 kgs (357.18 tonnes)

Recycling:

- Number of complaints regarding recycled materials:
 - Town - 0 complaints, Asselin's - 1 complaint
- Amount of recycled waste diverted from the landfill:
 - No Data - Emtera Environmental

Prepared By: _____

d. L. H.

Environmental & Facilities Superintendent

Date: _____

04-10-2015