

**TOWN OF FORT FRANCES**  
**Operations and Facilities Division - Environmental Area - Operations Statistics**  
**(April 2014)**



**STAFFING:**

See Operations Statistics (April) 2014 prepared by M. Strachan, Superintendent of Transportation

**OVERTIME HOURS - Equivalent Straight Time Hours**

See Operations Statistics (April) 2014 prepared by M. Strachan, Superintendent of Transportation

**WATER DISTRIBUTION:**

Water Main Breaks:

- Number of water main breaks: Six (6)
  - Mosher Ave. at Church St., 1336 Colonization Rd. W., Armit Ave. at Front St., 1602 Colonization Rd. W.
  - 1108 Christie Ave. N. and 116 First St. E.

Hydrant Repairs:

- Number of hydrant repairs: None

Hydrant Replacements:

- Number of hydrant replacements: None

Hydrant Installations (NEW):

- Number of new hydrant installations: None

Main Valve Repairs:

- Number of main valve repairs: None

Main Valve Replacements:

- Number of main valve replacements: One (1)
  - Armit Ave. at Front St. (VAL330)

Water Service Breaks:

- Number of water service breaks: Two (2)
  - 310 Church St. and 421 Sixth St. W.

Water Service Repairs:

- Number of water main valve repairs: None

Water Service Terminations:

- Number of water service repairs: None

Water Service Turn "Off/On":

- Number of water service turn "Off/On": Twelve (12)
  - 418 Scott St., 1007 Williams Ave., 1022 Williams Ave., 838 Third St. E., 622 Third St. E.,
  - 1205 Elizabeth St. E., 928 Frenette Ave., 1025 River Rd. W., 8 Armstrong Pl., 325 Scott St.,
  - 516 Third St. W. and 1028 Second St. E.

Frozen Water Services:

- Number of frozen water services: Ten (10)
  - 360 Third St. E., 1321 Idywild Dr., 362 Daniel Ave., 427 Sixth St. W., 622 Third St. E., 220 Church St.
  - 1205 Elizabeth St. E., 902 Phair Ave., 861 King's Hwy. and 201 Sixth St. W.

Water Meter Installations/Replacements:

- Number of water meter installations/replacements: None

Backflow Preventer Installations/Replacements:

- Number of backflow preventer installations/replacements: None

Backflow Preventer Annual Testing:

- Number of backflow preventer tested: Fourteen (14)
  - 110 Church St., 220 Church St., 427 Mowat Ave. (7) - Resolute F.P., 400 Mowat Ave., 1229 Cornwall Ave. N
  - 301 Nelson St., 303 Nelson St. and 101 Church St.

Other Information:

- Summarized final costs for invoicing of private works associated with private works
- Replaced missing markers on fire hydrants.
- April 9, 2014 - Completed lead sampling as per O. Reg. 170/03 (Distribution Only).
- April 23, 2014 - Tried to thaw water service line using the DBH machine - 375 Central Loop, Couchiching F.N.

**WATER TREATMENT PLANT:**

- April, 2014 - In receipt of the Water Treatment Facility Monthly Report.
- April 3, 2014 - Century Cranes in to complete the inspections of hoists and lifts.
- April 9, 2014 - Completed lead testing in the distribution system only.
- April 11, 2014 - Completed Water Treatment Plant monthly facility inspection.

**SEWERAGE COLLECTION:**

Wastewater Main Backups:

- Number of wastewater main backup: None

Sewer Main Repairs:

- Number of sewer main repairs: One (1)
  - 816 Nelson St.

Sewer Manhole Repairs:

- Number of sewer manhole repairs: Two (2)
  - Armit Ave. at Third St. E. Intersection and 645 Third St. W.

Sewer Service Repairs:

- Number of sewer service repairs: Two (2)
- 720 Armit Ave. and 426 Victoria Ave.

Sewer Service Terminations:

- Number of sewer service repairs: None

Sewer Service Replacements:

- Number of sewer service repairs: None

Other Information:

- Cleaned fourteen (14) plugged sewer services at the following locations:
  - 1229 Third St. E., 1024 Colonization Rd. W., 1227 Fifth St. E., 631 Third St. E., 440 Nelson St.,
  - 1204 Scott St., 1226 Third St. E., 1202 Third St. E., 702 Scott St., 1609 Colonization Rd. W.,
  - 375 Daniel Ave., 861 King's Hwy., 314 Second St. E. and 346 Church St.
- Traced various building sewer services.
- CCTV inspected various building sewer services.

**WASTE-WATER TREATMENT FACILITY:**

- April, 2014 - Received the Wastewater Treatment Facility Monthly Report.

**WASTE MANAGEMENT:**

Garbage Collection:

- Number of complaints regarding garbage collection:
  - Town - 0 complaints, Asselin's - 11 complaints

Sanitary Landfill (Waste Disposal Site):

Landfill Scales functioning properly during this period.

- Amount of residential waste delivered to the landfill:
  - 209,980 kgs (209.98 tonnes)
- Amount of ICI waste delivered to the landfill:
  - 279,010 kgs (279.01 tonnes)

Recycling:

- Number of complaints regarding recycled materials:
  - Town - 0 complaints, Asselin's - 0 complaints
- Amount of recycled waste diverted from the landfill:
  - 44,360 kgs (44.36 tonnes) Metro
- April 22, 2014 - Laidlaw hauled a load of glass to Nexcycle (28.83 tonnes).

Prepared By: \_\_\_\_\_



Environmental & Facilities Superintendent

Date: \_\_\_\_\_

27-05-2014