

Sewer & Water Data for 2022

up-dated June 16, 2022

Month	Days per month	2022	2022	2022	2022	2022	2022	2022	2022	2022	2022	2022-2021	2022-2021	2022	2022	Monthly Infiltration US Gallons
		Total	daily	Couch.	Couch.	Couch.	Total	daily	Couch.	Couch.	Couch.	Diff	Diff	Difference	Infiltration	
		Sewage	Sewage	Sewage	Sewage	Sewage	Treated	Treated	2 Water	2 Water	Water	Treated	Wastewater	STP-WTP	daily average	
		STP	STP	Meters	Meters	%	WTP	WTP	Meters	Meters	%	WTP	STP			
		cu. meters monthly	cu. meters daily	cu. meters monthly	cu. meters daily		cu. meters monthly	cu. meters daily	cu. meters monthly	cu. meters daily						
January	31	165767	5347.32	9178	296.06	5.54%	108550	3501.6	15229	491.2	14.03%	3190.0	10302.0	57217.0	1845.7	15,115,129
February	28	146159	5219.96	9649	344.61	6.60%	116300	4153.6	15229	543.9	13.09%	12410.0	-724.0	29859.0	1066.4	7,887,912
March	31	181143	5843.32	12116	390.84	6.69%	143250	4621.0	22373	721.7	15.62%	34130.0	21743.0	37893.0	1222.4	10,010,270
April	30	393808	13126.93	19882	662.73	5.05%	106280	3542.7	22373	745.8	21.05%	6880.0	167664.0	287528.0	9584.3	75,956,847
May	31	538725	17378.23	20199	651.58	3.75%	110630	3568.7		0.0	0.00%	-2660.0	359272.0	428095.0	13809.5	113,090,712
June	30		0.00		0.00	#DIV/0!		0.0		0.0	#DIV/0!	-135470.0	-144334.0	0.0	0.0	-
July	31		0.00		0.00	#DIV/0!		0.0		0.0	#DIV/0!	-178930.0	-142697.0	0.0	0.0	-
August	31		0.00		0.00	#DIV/0!		0.0		0.0	#DIV/0!	-139070.0	-146248.0	0.0	0.0	-
September	30		0.00		0.00	#DIV/0!		0.0		0.0	#DIV/0!	-99820.0	-162428.0	0.0	0.0	-
October	31		0.00		0.00	#DIV/0!		0.0		0.0	#DIV/0!	-96920.0	-175723.0	0.0	0.0	-
November	30		0.00		0.00	#DIV/0!		0.0		0.0	#DIV/0!	-93590.0	-180930.0	0.0	0.0	-
December	31		0.00		0.00	#DIV/0!		0.0		0.0	#DIV/0!	-102560	-174412.0	0.0	0.0	-
Total	365	1425602		71024			585010.0		75203.0			-792410.0	-568515.0	840592.0	2303.0	222,060,870
Monthly Average		285120.4	3909.6	14204.8	195.5	6.28%	117002.0	1615.6	18800.8	208.5	14.25%	16576.7	10440.3	41656.3	1378.2	11,004,437

Frog Creek Station equipment failure reporting negative flows. Reported here as 0  
Includes 27675m3 bypass volume at the plant due to extreme wet weather  
Includes 16930m3 bypass volume at the plant due to extreme wet weather

Couchiching experienced a watermain break in March just off of 5 Mile Dock Road