

**+The Corporation of the Town of Fort Frances
Wastewater Treatment Plant
(Sewage Plant)
February 2017 Monthly Operations Report**

INTRODUCTION

In accordance with the Agreement between the Ontario Clean Water Agency (Operating Authority) and the Town of Fort Frances, the Fort Frances Sewage Treatment Plant is required to prepare a monthly report. This document covers the reporting month of February 2017; the facility performance report summarizes important information regarding the quality of the effluent, wastewater, analytical test results, maintenance operations, and relevant activities of the WWTP.

DESCRIPTION OF WORKS

Capacity of Works	9000 m ³ /day (average flow)
Service Area	Town of Fort Frances and Couchiching Reserve
Service Population	9000
Effluent Receiver	Rainy River
Major Process	Secondary treatment facility complete with a phosphorus removal system; ultra violet disinfection; aerobic sludge stabilization and dewatering

The Fort Frances Sewage Treatment Plant operates under *Environmental Compliance Approval Number 6786-A44PWG*. The ECA outlines the terms and conditions, and the report captures these terms and conditions in the following sections.

LABORATORY

ALS Laboratory Group – Thunder Bay is contracted to conduct the required analytical tests of the influent (raw) and effluent samples; weekly requirement.

FEBRUARY 2017 EFFLUENT QUALITY

<i>Parameters</i>	<i>Monthly Actual Concentration mg/L</i>	<i>Compliance Criteria Concentration mg/L</i>	<i>Performance Objective Concentration mg/L</i>	<i>Monthly Actual Loading, kg/d</i>	<i>Compliance Criteria Loading kg/d</i>	<i>Performance Objective Loading kg/d</i>
CBOD ₅	2.3 mg/L	25 mg/L	15 mg/L	15.5 kg/d	225 kg/d	135 kg/d
Total Suspended Solids	5.8 mg/L	25 mg/L	15 mg/L	35.2 kg/d	225 kg/d	135 kg/d
Total Phosphorus	0.18 mg/L	1.0 mg/L	0.9 mg/L	1.1 kg/d	9 kg/d	8.1 kg/d
Total Nitrogen Nitrate Nitrogen	7.97 mg/L 5.64 mg/L					
Total Cl ₂ Residual		<0.01 mg/L (when in use)				
E-Coli		11.8 count/100 ml (geometric mean)		200 count/100ml (geometric mean)		E-coli not to exceed 150 organisms/100ml (monthly geometric mean density)
pH				pH range 7.3 to 7.8; average pH was 7.6		
Temperature degrees C				Temperatures ranged from 8.0 to 9.0 C; average temperature of effluent was 8.7 C		

Compliance criteria are mandatory requirements of the ECA and performance objectives are a goal to be achieved using best reasonable efforts.

WASTEWATER LIQUID PROCESS

The average daily flow for February was 6284.1 m³/day. This represents 70% of the design average flow. Total treated flow for the month was 175956 m³.

The Fort Frances WWTP met all effluent compliance criteria for the parameters listed above and additionally was well within the recommended more stringent monthly performance objective levels as outlined in the Environmental Compliance Approval.

INVENTORY

Chemical	End of Month Status	Units
Hypochlorite	1110 +/- @ 8.0% +3x205 L @ 12%	Litres
Alum	16.5 +/- @ 55 %	Cubic meters
Polymer	2x 205 L drums	Liters

MAINTENANCE

The operators performed the routine operations and maintenance at the treatment plant and pumping stations. The activities are highlighted as follows:

Treatment Plant:

- Alternated lead/lag pumps
- Adjusted fluidizing water to head cell and grit snail as needed
- Greased all blowers
- Regular cleaning of head works EW basket strainer
- Greased Grit Snail and lubricated drive chain
- Weekly inspection spiral screen access hatch, removed wrapped debris as required
- Drained and inspected clarifier 2
- Tightened drive chain on clarifier 2 longitudinal collector
- Drained aeration cell 1 to replace recirculation pump and repair gate
- Removed debris from spiral screen drain
- Adjusted the nut on the effluent outfall Milltronics head mount bracket

Pump Stations:

- Ran gensets
- Changed seal water strainers
- Adjusted the radio antenna at Church Street lift station
- Pulled and cleaned pump 1 at Central Avenue lift station and repaired strainer tubing
- Cleaned floats and reset PLC at Church Street lift station

OPERATIONAL ISSUES

There were no operational issues during the report period.

SLUDGE SUMMARY

Asselin Storage and Transportation Limited hauled a total of 63.3 m³ (11 bins) of thickened digested sludge to the Town of Fort Frances landfill site.

COMPLAINTS

There were no complaints during the report period.

BYPASS REPORT(S)

There were no bypass events during the report period.

COMMENTS

Plant power consumption for the month was 586 (x 180 multiplier) kWh.
Screen and Dewatering Upgrades at the FFWWTP have been under way since May 30, 2016.

REPORTS

ALS – Environmental Analytical Reports (on-file at plant)
Fort Frances WPCP Equipment Run Time Report (on-file at plant)
Bypass Report (on-file at plant as per occurrence)
Incident Report (on-file at plant as per occurrence)