

Workorder Summary Report

Report Start Date: Dec 1, 2019 12:00 AM
Report End Date: Dec 31, 2019 11:59 PM
Location: 1103*
Work Order Type: ADMIN,CALL,CAP,CORR,EMER,OPER,PM
Work Order Class:

				WorkOrder		PM Schedule		Workorder Details					
WO #	Asset ID	Asset Description	Location Description	Type	Class	FEQ	Units	Work Order Description	Status	Schedule Start	Actual Start	Actual Finsh	WorkLog Detail
1534505	0000246428	PUMP CENT BOUNDARY P1	1103, Boundary Pumping Station, Process	CALL	Refurbish/ Replace/Repair	0		Boundary Lift Station High Level 1103	COMP		12/2/19 07:10 AM	12/2/19 07:18 AM	Boundary LS High Level -I arrived onsite to find multiple alarms from the lift station, After closer examination it would appear that it had a power failure which caused the alarms. All of the alarms cleared and I stayed to monitor.
1535550			1103, Fort Frances WPCP	CALL	Refurbish/ Replace/Repair	0		Digester doghouse low temp alarm call in 1103	COMP		12/10/19 09:30 PM	12/10/19 11:00 PM	Digester doghouse low temp alarm call in 1103 -I was called by the auto dialer at 2130 hours for a digester doghouse low temperature alarm. I called Communique Action and drove to the plant where I acknowledged the alarm and checked on the heaters in question. A heater fan had stopped working so I replaced with a spare unit. All was okay at 2300 hours so I closed my ticket and went home.
1536103	0000129811	METER LEVEL MILLTRONIC BYPASS FLOW	1103, Fort Frances WPCP, Process, Process Control & Monitoring	CALL	Refurbish/ Replace/Repair	0		Manhole 8 High Level 1103	COMP		12/16/19 07:36 AM	12/16/19 07:42 AM	Manhole 8 High Level Alarm -I arrived onsite and reviewed trending to find that the milltronics had spiked due to cold weather . I then visually inspected Manhole 8 to find it to be normal so I reset the alarm.
1536378	0000129846	ENGINE DIESEL GENERATOR	1103, Central Ave Pumping Station, Facility	CALL	Refurbish/ Replace/Repair	0		Central Genset Fault 1103	COMP		12/18/19 09:21 AM	12/18/19 09:31 AM	Central Genset Failure -I received the call and when I arrived at Central lift station Wajax was onsite testing the genset unit . I reminded him of the time and that this was not the plan, I Then returned to the plant to reset the alarm.
1531321	0000227376	PANEL ALARM/ DIALER	1103, Fort Frances WPCP, Process, Process Control & Monitoring	PM	Inspection	1	MONTHS	Critical Alarm/Dialer Testing (1m) 1103	COMP	12/1/19 12:00 AM	1/1/20 09:22 AM	1/1/20 09:22 AM	Dialer Test -We test daily at 11 am.
1531325			1103, Fort Frances WPCP	PM	Refurbish/ Replace/Repair	1	MONTHS	Diesel Gensets Inspection/ Functional Tests (1m) 1103	COMP	12/1/19 12:00 AM	12/2/19 07:29 AM	12/2/19 07:29 AM	Genset Maint. -I ran both portable gensets and the others were exercised earlier in the month.

Workorder Summary Report

Report Start Date: Dec 1, 2019 12:00 AM

Report End Date: Dec 31, 2019 11:59 PM

Location: 1103*

Work Order Type: ADMIN,CALL,CAP,CORR,EMER,OPER,PM

Work Order Class:

				WorkOrder		PM Schedule		Workorder Details					
WO #	Asset ID	Asset Description	Location Description	Type	Class	FEQ	Units	Work Order Description	Status	Schedule Start	Actual Start	Actual Finsh	WorkLog Detail
1531341			1103, Fort Frances WPCP	PM	Health and Safety	1	MONTHS	Health And Safety Inspection (1m) 1103	COMP	12/1/19 12:00 AM	1/1/20 09:25 AM	1/1/20 09:25 AM	H&S Inspection -Main building garage door opener needs repair, The Town is contacting supplier.
1531356			1103, Fort Frances WPCP	PM	Inspection	1	MONTHS	TPM Inspection/Maintenance (1m) 1103	COMP	12/1/19 12:00 AM	1/5/20 10:11 AM	1/5/20 10:11 AM	
1531688			1103, Fort Frances WPCP	PM	Inspection	1	MONTHS	Blowers/Motors Inspection/Service (1m/3m) 1103	COMP	12/1/19 12:00 AM	1/1/20 06:30 AM	1/1/20 07:30 AM	Blower Maint. -I changed oil in blowers 3 & 4 and greased all others.
1531698	0000246402	CENTRIFUGE GS2-2-1 TEACUP/ GRIT SNAIL	1103, Fort Frances WPCP, Process, Primary Treatment, Primary Sludge Degritting	PM	Inspection	1	MONTHS	Teacup Centrifuge Inspection/ Service (1m/3m/1y) 1103	COMP	12/1/19 12:00 AM	12/25/19 08:51 AM	12/25/19 08:51 AM	Teacup Centrifuge Inspection/ Service (1m/3m/1y) 1103 -Drained and inspected teacup - no debris. Drained and hosed snail. Greased bearings and lubricated drive chain.
1531718			1103, Fort Frances WPCP	PM	Refurbish/ Replace/Repair	3	MONTHS	Clarifiers Inspection/Service (3m) 1103	COMP	12/1/19 12:00 AM	12/25/19 08:55 AM	12/25/19 08:55 AM	Clarifiers Inspection/Service (3m) 1103 -Greased all clarifier drives. Running smooth and quiet
1532119			1103, Fort Frances WPCP	PM	Refurbish/ Replace/Repair	1	YEARS	Pump Centrifugal Grit Pumps Inspection/Service (1y) 1103	COMP	12/1/19 12:00 AM	12/20/19 02:29 PM	12/20/19 02:29 PM	