

Workorder Summary Report

Report Start Date: Feb 1, 2022 12:00 AM

Report End Date: Feb 28, 2022 11:59 PM

Location: 1103*

Work Order Type: ADMIN,CALL,CAP,CORR,EMER,OPER,PM

Work Order Class:

				WorkOrder		PM Schedule		Workorder Details					
WO #	Asset ID	Asset Description	Location Description	Type	Class	FEQ	Units	Work Order Description	Status	Schedule Start	Actual Start	Actual Finsh	WorkLog Detail
2661288			1103, Fort Frances WPCP	OPER	Inspection	1	MONTHS	Snow Removal at Wastewater Treatment (1m) 1103	COMP	2/1/22 12:00 AM	3/7/22 07:02 AM	3/7/22 07:02 AM	
2672911	0000227376	PANEL ALARM/DIALER	1103, Fort Frances WPCP, Process, Process Control & Monitoring	PM	Inspection	1	MONTHS	Critical Alarm/Dialer Testing (1m) 1103	COMP	2/1/22 12:00 AM	2/28/22 11:00 AM	2/28/22 12:00 PM	Dialer Test -We Test daily .
2672915			1103, Fort Frances WPCP	PM	Refurbish/Replace/Repair	1	MONTHS	Diesel Gensets Inspection/Functional Tests (1m) 1103	COMP	2/1/22 12:00 AM	2/28/22 09:00 AM	2/28/22 11:00 AM	Genset Maint. -We run under load for 1 hour.
2672931			1103, Fort Frances WPCP	PM	Health and Safety	1	MONTHS	Health And Safety Inspection (1m) 1103	COMP	2/1/22 12:00 AM	2/27/22 01:00 PM	2/27/22 02:00 PM	H&S Inspection -No new issues but the rust in the plow truck still not replaced.
2672942			1103, Fort Frances WPCP	PM	Inspection	1	MONTHS	TPM Inspection/Maintenance (1m) 1103	COMP	2/1/22 12:00 AM	3/7/22 06:59 AM	3/7/22 06:59 AM	
2673266			1103, Fort Frances WPCP	PM	Inspection	1	MONTHS	Blowers/Motors Inspection/Service (1m/3m) 1103	COMP	2/1/22 12:00 AM	2/27/22 11:30 AM	2/27/22 12:30 PM	Blower Maint. -I changed oil and greased both blowers 3 & 4
2673274	0000246402	CENTRIFUGE GS2-2-1 TEACUP/GRIT SNAIL	1103, Fort Frances WPCP, Process, Primary Treatment, Primary Sludge Degritting	PM	Inspection	1	MONTHS	Teacup Centrifuge Inspection/Service (1m/3m/1y) 1103	COMP	2/1/22 12:00 AM	2/27/22 07:45 AM	2/27/22 08:45 AM	Teacup Inspection -I inspected the teacup and found minimal debris.