

Workorder Summary Report

Report Start Date: May 1, 2021 12:00 AM

Report End Date: May 31, 2021 11:59 PM

Location: 1103*

Work Order Type: ADMIN,CALL,CAP,CORR,EMER,OPER,PM

Work Order Class:

				WorkOrder		PM Schedule		Workorder Details					
WO #	Asset ID	Asset Description	Location Description	Type	Class	FEQ	Units	Work Order Description	Status	Schedule Start	Actual Start	Actual Finsh	WorkLog Detail
2250385			1103, Fort Frances WPCP	OPER	Inspection	1	MONTHS	Snow Removal at Wastewater Treatment (1m) 1103	COMP	5/1/21 12:00 AM	5/31/21 01:47 PM	5/31/21 01:47 PM	
2261261	0000227376	PANEL ALARM/DIALER	1103, Fort Frances WPCP, Process, Process Control & Monitoring	PM	Inspection	1	MONTHS	Critical Alarm/Dialer Testing (1m) 1103	COMP	5/1/21 12:00 AM	5/27/21 11:00 AM	5/27/21 12:00 PM	Dialer Test -We test daily at 11.
2261265			1103, Fort Frances WPCP	PM	Refurbish/Replace/Repair	1	MONTHS	Diesel Gensets Inspection/Functional Tests (1m) 1103	COMP	5/1/21 12:00 AM	5/24/21 10:00 AM	5/24/21 12:00 PM	Monthly Gensets -I ran all gensets for 1 hour under load.
2261281			1103, Fort Frances WPCP	PM	Health and Safety	1	MONTHS	Health And Safety Inspection (1m) 1103	COMP	5/1/21 12:00 AM	5/26/21 11:30 AM	5/26/21 12:30 PM	Monthly H&S -No issues observed .
2261607			1103, Fort Frances WPCP	PM	Inspection	1	MONTHS	Blowers/Motors Inspection/Service (1m/3m) 1103	COMP	5/1/21 12:00 AM	5/26/21 09:15 AM	5/26/21 11:15 AM	Monthly Blower Maint. -I changed oil in blowers 4 & 5 and greased.
2261615	0000246402	CENTRIFUGE GS2-2-1 TEACUP/GRIT SNAIL	1103, Fort Frances WPCP, Process, Primary Treatment, Primary Sludge Degritting	PM	Inspection	1	MONTHS	Teacup Centrifuge Inspection/Service (1m/3m/1y) 1103	COMP	5/1/21 12:00 AM	5/31/21 01:46 PM	5/31/21 01:46 PM	Teacup Centrifuge Inspection/Service (1m/3m/1y) 1103 -Greased bearings and lubricated drive chain on grit snail. Cleaned debris from snail scraper