

TOWN OF FORT FRANCES
Operations and Facilities Division - Environmental Area - Operations Statistics
(June 2013)



STAFFING:

See Operations Statistics (June) 2013 prepared by M. Strachan, Superintendent of Transportation

OVERTIME HOURS - Equivalent Straight Time Hours

See Operations Statistics (June) 2013 prepared by M. Strachan, Superintendent of Transportation

WATER DISTRIBUTION:

Water Main Breaks:

- Number of water main breaks: One (1)
- In front of 214 Sixth St. W.

Hydrant Repairs:

- Number of hydrant repairs: None

Hydrant Replacements:

- Number of hydrant replacements: Two (2)
- Holmes Ave. at Thompson St. (HYD143) and Cornwall Ave. N. at Eighth St. W. (HYD071)

Hydrant Installations (NEW):

- Number of new hydrant installations: None

Main Valve Repairs:

- Number of water main valve repairs: None

Main Valve Replacements:

- Number of water main valve repairs: Two (2)
- In front of 654 Thompson St. (VAL599) and in front of 350 McIrvine Rd. (VAL047)

Water Service Breaks:

- Number of water service breaks: Two (2)
- 308 Kerr Pl. and 401 King's Hwy.

Water Service Repairs:

- Number of water service repairs: Three (3)
- 301 Kerr Pl., 342 Scott St. and 1319 Colonization Rd. W.

Water Service Installations (NEW):

- Number of water service installations: None

Water Service Replacements:

- Number of water service installations: None

Water Service Terminations:

- Number of water service terminations: None

Water Service Turn "Off/On":

- Number of water service turn "Off/On": Eleven (11)
 - 818 Minnie Ave., 301 Kerr Pl., 935 Victoria Ave. N., 1214 Third St. E., 1034 Christie Ave. N.,
 - 474 Scott St. (2), 1007 Victoria Ave. N. (2) and 420 Sixth St. W. (2)

Frozen Water Services:

- Number of frozen water services: None

Water Meter Installations/Replacements:

- Number of water meter installations/replacements: Two (2)
 - 401 King's Hwy. and 540 King's Hwy.

Backflow Preventer Installations/Replacements:

- Number of backflow preventer installations/replacements: Two (2)
 - 401 King's Hwy. and 540 King's Hwy.

Backflow Prevention - Testing:

- Number of backflow preventers tested: Eighteen (18)
 - 922 Scott St. (3), 353 Church St., 1450 Idylwild Dr., 265 Scott St., 401 King's Hwy. and 130 Second St. E. (6)
 - 333 Church St. and 520 Eighth St. E. (4)

Other Information:

- Summarized final costs for invoicing of private works associated with private works
- Traced various building water services.
- Worked in conjunction with Wagner Construction to disinfect and test water quality before putting the temporary water service line (Williams Ave. - Third St. E. to Fifth St. E.) into service.
- Worked in conjunction with Wagner Construction to replace fire hydrants and valves at various locations within the Town.
- Continued with the valve exercising program (Area 3)
- Recorded locations of curb stops at various locations.

WATER TREATMENT PLANT:

- June, 2013 - In receipt of the Water Treatment Facility Monthly Report.

SEWERAGE COLLECTION:

Wastewater Main Backups:

- Number of wastewater main backup: None

Wastewater Main Repairs:

- Number of wastewater main repairs: None

Wastewater Manhole Repairs:

- Number of wastewater manhole repairs: None

Sewer Service Repairs:

- Number of sewer service repairs: One (1)
 - 214 Sixth St. W.

Sewer Service Replacements:

- Number of sewer service installations: None

Sewer Service Installations (NEW):

- Number of sewer service installations: None

Sewer Service Terminations:

- Number of water service terminations: None

Other Information:

- Cleaned six (6) plugged sewer services at the following locations:
 - 400 Third St. E., 623 Second St. E., 428 First St. E., 520 First St. E., 831 King's Hwy. and 755 Riverview Dr.
- June 14, 2013 - Cleaned out sump pit and flushed/clean sanitary line for Ainsworth Engineering Canada Corp. in Barwick.
- June 17 - 24, 2013 - Root Rooter in Town to clean and televise sanitary sewer mains.
- CCTV inspected and traced various building sewer services.
- Performed connection inspections at 353 Church St. and 509 Victoria Ave. (Private Work)
- Recorded locations of cleanouts at various locations.
- Sewer main flushing - Areas 5, 10 and other areas of concern.

WASTE-WATER TREATMENT FACILITY:

- July 18, 2013 - In receipt of the Wastewater Treatment Facility Monthly Report for June 2013.

WASTE MANAGEMENT:

Garbage Collection:

- Number of complaints regarding garbage collection:
 - Town - 0 complaints, Asselin's - 6 complaints

Sanitary Landfill (Waste Disposal Site):

Landfill Scales functioning properly during this period.

- Amount of residential waste delivered to the landfill:
 - 300,210 kgs (300.21 tonnes)
- Amount of ICI waste delivered to the landfill:
 - 1,233,380 kgs (1,233.38 tonnes)

Recycling:

- Number of complaints regarding recycled materials:
 - Town - 0 complaints, Asselin's - 0 complaints
- Amount of recycled waste diverted from the landfill:
 - 45,050 kgs (45.05 tonnes) Cascade Recovery Inc.

Prepared By: J-L H-

Environmental & Facilities Superintendent

Date: 18-07-2013