

Workorder Summary Report

Report Start Date: Dec 1, 2020 12:00 AM

Report End Date: Dec 31, 2020 11:59 PM

Location: 1103*

Work Order Type: ADMIN,CALL,CAP,CORR,EMER,OPER,PM

Work Order Class:

				WorkOrder		PM Schedule		Workorder Details					
WO #	Asset ID	Asset Description	Location Description	Type	Class	FEQ	Units	Work Order Description	Status	Schedule Start	Actual Start	Actual Finsh	WorkLog Detail
2033618	0000227376	PANEL ALARM/ DIALER	1103, Fort Frances WPCP, Process, Process Control & Monitoring	PM	Inspection	1	MONTHS	Critical Alarm/Dialer Testing (1m) 1103	COMP	12/1/20 12:00 AM	12/20/20 11:00 AM	12/20/20 12:00 PM	Dialer Test -We test daily.
2033622			1103, Fort Frances WPCP	PM	Refurbish/ Replace/Repair	1	MONTHS	Diesel Gensets Inspection/ Functional Tests (1m) 1103	COMP	12/1/20 12:00 AM	12/14/20 07:45 AM	12/14/20 07:45 AM	Diesel Gensets Inspection/ Functional Tests -Exercised gensets at Central Avenue, Fifth Street and White Pine lift stations. All good. Kelly C
2033638			1103, Fort Frances WPCP	PM	Health and Safety	1	MONTHS	Health And Safety Inspection (1m) 1103	COMP	12/1/20 12:00 AM	12/20/20 10:45 AM	12/20/20 11:45 AM	H&S Inspection -No issues this month.
2033970			1103, Fort Frances WPCP	PM	Inspection	1	MONTHS	Blowers/Motors Inspection/Service (1m/3m) 1103	COMP	12/1/20 12:00 AM	12/19/20 09:15 AM	12/19/20 10:15 AM	Blower Maint. -I greased all blowers.
2033980	0000246402	CENTRIFUGE GS2-2-1 TEACUP/ GRIT SNAIL	1103, Fort Frances WPCP, Process, Primary Treatment, Primary Sludge Degritting	PM	Inspection	1	MONTHS	Teacup Centrifuge Inspection/ Service (1m/3m/1y) 1103	COMP	12/1/20 12:00 AM	12/22/20 07:30 AM	12/22/20 08:30 AM	Teacup Maint. -I removed the lid and found minimal debris. I then returned it to service.
2033997			1103, Fort Frances WPCP	PM	Refurbish/ Replace/Repair	3	MONTHS	Clarifiers Inspection/Service (3m) 1103	COMP	12/1/20 12:00 AM	1/4/21 01:45 PM	1/4/21 02:45 PM	Clarifier Maint. -I greased both clarifiers.DH
2034388			1103, Fort Frances WPCP	PM	Refurbish/ Replace/Repair	1	YEARS	Pump Centrifugal Grit Pumps Inspection/Service (1y) 1103	COMP	12/1/20 12:00 AM	12/23/20 02:42 PM	12/23/20 02:42 PM	Pump Centrifugal Grit Pumps Inspection/Service -Changed oil in both grit pump gear boxes. Kelly C