Ontario Clean Water Agency
Agence Ontarienne Des Eaux

Fort Frances WPCP
200 McIrvine Rd
Fort Frances, Ontario
P9A 3S3
Tel: 807-274-3121
Fax: 807-274-8381

February 11, 2016

Town of Fort Frances
320 Portage Avenue
Fort Frances Ontario
P9A 3M5

Attention: Mr. Doug Herr
Environmental and Facilities Superintendent

Dear Doug:

Re: Fort Frances Wastewater Treatment Facility
January 2016 Monthly Report

As per the operating agreement, the attached document is the January 2016 monthly report for the Fort Frances Wastewater Treatment Facility.

The report highlights the influent and effluent quality and the process parameters. Additionally, the routine operation and maintenance activities conducted by the operators are summarized.

If you have any questions regarding this report do not hesitate to contact Mr. Larry Wachter – Operations Manager.

Yours truly,

Kelly Cunningham
Senior Operator

For Larry Wachter
Operations Manager

The Corporation of the Town of Fort Frances
Wastewater Treatment Plant
(Sewage Plant)
January 2016 Monthly Operations Report

INTRODUCTION

In accordance with the Agreement between the Ontario Clean Water Agency (Operating Authority) and the Town of Fort Frances, the Fort Frances Sewage Treatment Plant is required to prepare a monthly report. This document covers the reporting month of January 2016; the facility performance report summarizes important information regarding the quality of the effluent, wastewater, analytical test results, maintenance operations, and relevant activities of the WWTP.

DESCRIPTION OF WORKS

Capacity of Works	9000 m^3/day (average flow)
Service Area	Town of Fort Frances and Couchiching Reserve
Service Population	9000
Effluent Receiver	Rainy River
Major Process	Secondary treatment facility complete with a phosphorus removal system; ultra violet disinfection; aerobic sludge stabilization and dewatering

The Fort Frances Sewage Treatment Plant received and operates its operation under *Certificate of Approval Number 3-0049-96-006,* in accordance with Section 53 of the Ontario Water Resources Act. The Certificate of Approval outlines the terms and conditions and the report captures these terms and conditions in the following sections.

LABORATORY

ALS Laboratory Group – Thunder Bay is contracted to conduct the required analytical tests of the influent (raw) and effluent samples; weekly requirement.

JANUARY 2016 EFFLUENT QUALITY

Parameters	***Monthly Actual Concentration* mg/L**	***Compliance Criteria Concentration* mg/L**	***Performance Objective Concentration*** mg/L	***Monthly Actual Loading, kg/d***	***Compliance Criteria Loading kg/d***	***Performance Objective Loading* kg/d**
$CBOD_5$	2.4 mg/L	25 mg/L	15 mg/L	13.5 kg/d	225 kg/d	135 kg/d
Suspended Solids	6.0 mg/L	25 mg/L	15 mg/L	34.7 kg/d	225 kg/d	135 kg/d
Total Phosphorus	0.15 mg/L	1.0 mg/L	1.0 mg/L	0.8 kg/d	9 kg/d	9 kg/d
Ammonia as N Nitrite as N Nitrate as N	0..65 mg/L 0.19 mg/L 5.77 mg/L					
Total Cl_2 Residual		<0.01 mg/L (when in use)				
E-Coli		23.7 count/100 ml (geometric mean)		200 count/100ml (geometric mean)		E-coli not to exceed 150 organisms/100ml (monthly geometric mean density)
pH				pH range 7.3 to 7.9; average pH was 7.6		
Temperature degrees C				Temperatures ranged from 9.0 – 10.5 average temperature of effluent at 9.8		

Compliance criteria are mandatory requirements of the C of A and performance objectives are a goal to be achieved using best reasonable efforts.

WASTEWATER LIQUID PROCESS

The average daily flow for January was 5668.1 m^3 /day. This represents 63% of the design average flow. Total treated flow for the month was 175712 m^3.
The Fort Frances WWTP met all effluent compliance criteria for the parameters listed above and additionally was well within the recommended more stringent monthly performance objective levels as outlined in the Certificate of Approval.

INVENTORY

Chemical	End of Month Status	Units
Hypochlorite	1160 +/-@ 7.0% + 410 @ 12%	Litres
Alum	18.2 +/- @ 60 %	Cubic meters
Polymer	31 Bags (125 kg)	Bags (775 kg/bag)

MAINTENANCE

The operators performed the routine operations and maintenance at the treatment plant and pumping stations. The activities are highlighted as follows:

Treatment Plant:

- Alternated lead/lag pumps
- Adjusted fluidizing water to head cell and grit snail as needed
- Greased GBT, mechanical bar screen and grit snail. Lubricated drive chain on grit snail and bar screen
- Regular cleaning of head works EW basket strainer
- Replaced hydraulic hose on grit trailer
- Regular cleaning of seal water strainer TFP 9-5
- Greased all blowers
- Put an additional heater in the digester dog house
- Repaired drywall in lunch room and painted walls
- Pressure washed GBT and walls
- Cleaned DO probes
- Chlorinated sampler lines
- Painted walls in garage stairwell
- Changed filter blower 2
- Removed ice and snow from scum lids
- Replaced motion light switches in lower basement
- Adjusted the gate and latch

Pump Stations:

- Ran gensets
- Changed seal water strainers
- Cleaned bar screens
- Reset breakers and PLC at Boundary Road lift station

OPERATIONAL ISSUES

There were no operational issues in the report period.

SLUDGE SUMMARY

The volume directed to the gravity belt thickener totaled 553.7 m3 for the month. Asselin Transportation and Storage Limited hauled a total of 249.9 m3 of thickened digested sludge (average of 11.9 m3/load) to the Town of Fort Frances landfill site.

COMPLAINTS

There were no complaints during the report period.

BY-PASS REPORT(S)

There were no bypass events in the report period.

COMMENTS

Plant power consumption for the month was 687 (x 180 multiplier) kWh.
A daily automatic SCADA generated test alarm of the auto dialer has been programmed.
Quarterly sludge samples were sent to ALS Laboratories for analysis.

REPORTS

ALS – Environmental Analytical Reports (on-file at plant)
Fort Frances WPCP Equipment Run Time Report (on-file at plant)
Bypass Report (on-file at plant as per occurrence)

Month	Avg. Day Flow m3	Sewage Flows Year 2016 Max Day Flow m3	Total Treated Volume ML	Total ByPass Volume ML	Total Volume ML	Usage % Plant Capacity	Sludge Volume Hauled M3
January	5668.1	5900	175712		175712	63%	249.9
February						0%	
March						0%	
April						0%	
May						0%	
June						0%	
July						0%	
August						0%	
September						0%	
October						0%	
November						0%	
December						0%	
Sum				0	175712		249.9
Average	5668		175712		175712	63%	249.9
Max		5900	175712		175712		
C of A	9000	18000					

Removal Efficiency	
CBOD5	0.972413793
Suspended Solids	0.957865169
Total Phosphorus	0.937759336

	CBOD5			Suspended Solids			Total Phosphorus			E. Coli		pH
	Avg Raw	Avg. Eff.	Avg. Load	Avg Raw	Avg. Eff.	Avg. Load	Avg Raw	Avg. Eff.	Avg. Load	Geo Mean	Monthly	Monthly
Month	CBOD	CBOD	CBOD	S.S	S.S	S.S	T.P	T.P	T.P	Counts	Minimum	Maximum
	(mg/L)	(mg/L)	(kg/day)	(mg/L)	(mg/L)	(kg/day)	(mg/L)	(mg/L)	(kg/day)	/100ml		
January	87.0	2.4	13.5	142.4	6.0	34.7	2.41	0.15	0.83	23.7	7.3	7.9
February												
March												
April												
May												
June												
July												
August												
September												
October												
November												
December												
Average	87.0	2.4	13.5	142.4	6.0	34.7	2.4	0.15	0.83	23.7	7.3	7.9
Max	87	2.4	13.5	142.4	6	34.7	2.4	0.15	0.83	23.7	7.3	7.9
C of A		25	225		25	225		1	9	200	6.0	9.5