

Workorder Summary Report

Report Start Date: Feb 1, 2021 12:00 AM

Report End Date: Feb 28, 2021 11:59 PM

Location: 1103\*

Work Order Type: ADMIN,CALL,CAP,CORR,EMER,OPER,PM

Work Order Class:

				WorkOrder		PM Schedule		Workorder Details					
WO #	Asset ID	Asset Description	Location Description	Type	Class	FEQ	Units	Work Order Description	Status	Schedule Start	Actual Start	Actual Finsh	WorkLog Detail
<a href="#">2133050</a>	0000129811	METER LEVEL MILLTRONIC BYPASS FLOW	1103, Fort Frances WPCP, Process, Process Control & Monitoring	CALL	Refurbish/ Replace/Repair	0		Manhole #8 High Level 1103	COMP		2/18/21 07:43 AM	2/18/21 07:47 AM	Manhole #8 High Level -I arrived onsite to find manhole #8 sensor to be acting erratic . After an hour it began to act normal, Due to extreme cold temps here.
<a href="#">2134047</a>			Fort Frances Water Pollution Control Plant	CALL	Refurbish/ Replace/Repair	0		Basement sump high level alarm call back	COMP		2/22/21 04:35 PM	2/22/21 06:00 PM	Basement sump high level alarm call back -A basement sump high level alarm call in at 1635 hours. When I got to the plant I acknowledged the alarm on the SCADA computer. I then reset the main power on the sump panel as well as both pump disconnects. I added water to the sump pit and was able to pump the water level down and both pumps functioned without any problem.
<a href="#">2116516</a>			1103, Fort Frances WPCP	OPER	Inspection	1	MONTHS	Snow Removal at Wastewater Treatment (1m) 1103	COMP	2/1/21 12:00 AM	3/7/21 03:46 PM	3/7/21 03:46 PM	
<a href="#">2126752</a>			1103, Fort Frances WPCP	OPER	Compliance	1	MONTHS	WISKI Review (1m) 1103	COMP	2/1/21 12:00 AM	3/9/21 03:51 PM	3/9/21 03:51 PM	
<a href="#">2126716</a>	0000227376	PANEL ALARM/ DIALER	1103, Fort Frances WPCP, Process, Process Control & Monitoring	PM	Inspection	1	MONTHS	Critical Alarm/Dialer Testing (1m) 1103	COMP	2/1/21 12:00 AM	2/27/21 11:00 AM	2/27/21 12:00 PM	Dialer Test -We test daily @ 11
<a href="#">2126720</a>			1103, Fort Frances WPCP	PM	Refurbish/ Replace/Repair	1	MONTHS	Diesel Gensets Inspection/ Functional Tests (1m) 1103	COMP	2/1/21 12:00 AM	2/21/21 03:39 PM	2/21/21 03:39 PM	Diesel Gensets Inspection/ Functional Tests (1m) 1103 -I exercised all lift station diesel generators and the Yamaha portable generator, Kelly C
<a href="#">2126736</a>			1103, Fort Frances WPCP	PM	Health and Safety	1	MONTHS	Health And Safety Inspection (1m) 1103	COMP	2/1/21 12:00 AM	2/28/21 10:00 AM	2/28/21 11:00 AM	Monthly H&S Inspection -No issues found.
<a href="#">2126747</a>			1103, Fort Frances WPCP	PM	Inspection	1	MONTHS	TPM Inspection/Maintenance (1m) 1103	COMP	2/1/21 12:00 AM	3/7/21 03:45 PM	3/7/21 03:45 PM	
<a href="#">2127070</a>			1103, Fort Frances WPCP	PM	Inspection	1	MONTHS	Blowers/Motors Inspection/Service (1m/3m) 1103	COMP	2/1/21 12:00 AM	2/28/21 12:00 PM	2/28/21 01:00 PM	Blower Maint. -I greased all blowers and checked air filters.

Workorder Summary Report

Report Start Date: Feb 1, 2021 12:00 AM

Report End Date: Feb 28, 2021 11:59 PM

Location: 1103\*

Work Order Type: ADMIN,CALL,CAP,CORR,EMER,OPER,PM

Work Order Class:

				WorkOrder		PM Schedule		Workorder Details					
WO #	Asset ID	Asset Description	Location Description	Type	Class	FEQ	Units	Work Order Description	Status	Schedule Start	Actual Start	Actual Finsh	WorkLog Detail
<a href="#">2127078</a>	0000246402	CENTRIFUGE GS2-2-1 TEACUP/ GRIT SNAIL	1103, Fort Frances WPCP, Process, Primary Treatment, Primary Sludge Degritting	PM	Inspection	1	MONTHS	Teacup Centrifuge Inspection/ Service (1m/3m/1y) 1103	COMP	2/1/21 12:00 AM	2/25/21 01:00 PM	2/25/21 02:00 PM	Teacup Maint. -I removed the lid and inspected the teacup and found minimal debris .