

TOWN OF FORT FRANCES
Operations and Facilities Division - Environmental Area - Operations Statistics
February-21

STAFFING:

See Operations Statistics prepared by M. Strachan, Superintendent of Transportation

OVERTIME HOURS - Equivalent Straight Time Hours

See Operations Statistics prepared by M. Strachan, Superintendent of Transportation

WATER DISTRIBUTION & WASTE WATER COLLECTION:

See Monthly Summary (Attached)
Misc. water turn on / off
11 Frozen water lines
Resumed working on plugged sewers in yellow control zone
Pulled sewer mains - 6th st w / walker / hudson area
Repaired sewer service @ 428 victoria

WATER TREATMENT PLANT:

February 2021 - In receipt of the Water Treatment Plant Monthly Report
Jeff St, Pierre of OCWA is temporary ORO at WTP until TOFF has a Class 3 operator
P. LeMesurier notified of passing grade for WT3 exam
J. Bruyere cross - training at WTP
Maintained rotation at WTP to 2 employees due to Covid-19 restrictions

WASTE-WATER TREATMENT FACILITY:

February 2021 - In receipt of the Wastewater Treatment Facility Monthly Report.

WASTE MANAGEMENT:

Garbage Collection:

Garbage not picked up - 12 houses (variety of reasons)

Sanitary Landfill (Waste Disposal Site):

Landfill Scales occasionally not functioning during this period. During thaws and freeze / thaw causing the electronics to behave erratically.

Amount of residential waste (kg) delivered to the landfill:
139,100

Amount of ICI waste (kg) delivered to the landfill:
242,800

Recycling:

Recycle not picked up - 23 houses (mostly contamination)

Amount of recycled waste (Metric Tonnes) diverted from the landfill:
No Data (Emterra)

Prepared By: Craig Miller, P.Eng. Environmental Superintendent

Date: 15-Mar-21