

Workorder Summary Report

Report Start Date: Sep 1, 2021 12:00 AM
Report End Date: Sep 30, 2021 11:59 PM
Location: 1103*
Work Order Type: ADMIN,CALL,CAP,CORR,EMER,OPER,PM
Work Order Class:

				WorkOrder		PM Schedule		Workorder Details					
WO #	Asset ID	Asset Description	Location Description	Type	Class	FEQ	Units	Work Order Description	Status	Schedule Start	Actual Start	Actual Finsh	WorkLog Detail
2433618			1103, Fort Frances WPCP	OPER	Inspection	1	MONTHS	Grass Cutting at Wastewater Treatment (1m) 1103	COMP	9/1/21 12:00 AM	10/3/21 12:04 PM	10/3/21 12:04 PM	
2445769	0000227376	PANEL ALARM/DIALER	1103, Fort Frances WPCP, Process, Process Control & Monitoring	PM	Inspection	1	MONTHS	Critical Alarm/Dialer Testing (1m) 1103	COMP	9/1/21 12:00 AM	9/27/21 11:00 AM	9/27/21 12:00 PM	Dialer Test -We test daily.
2445773			1103, Fort Frances WPCP	PM	Refurbish/Replace/Repair	1	MONTHS	Diesel Gensets Inspection/Functional Tests (1m) 1103	COMP	9/1/21 12:00 AM	9/28/21 06:57 AM	9/28/21 06:57 AM	Monthly Gensets -Gensets ran for 4 hours during power outage.
2445799			1103, Fort Frances WPCP	PM	Health and Safety	1	MONTHS	Health And Safety Inspection (1m) 1103	COMP	9/1/21 12:00 AM	9/26/21 07:30 AM	9/26/21 08:30 AM	Monthly H&S -No issues.
2445810			1103, Fort Frances WPCP	PM	Inspection	1	MONTHS	TPM Inspection/Maintenance (1m) 1103	COMP	9/1/21 12:00 AM	10/3/21 12:09 PM	10/3/21 12:09 PM	
2445815			1103, Fort Frances WPCP	OPER	Health and Safety	1	YEARS	WHMIS/MSDS/NSF Review And Update (1y) 1103	COMP	9/1/21 12:00 AM	10/8/21 06:51 AM	10/8/21 06:51 AM	
2446134			1103, Fort Frances WPCP	PM	Inspection	1	MONTHS	Blowers/Motors Inspection/Service (1m/3m) 1103	COMP	9/1/21 12:00 AM	9/30/21 07:00 AM	9/30/21 08:00 AM	Monthly Blower Maint. -I greased all blowers.
2446144	0000246402	CENTRIFUGE GS2-2-1 TEACUP/GRIT SNAIL	1103, Fort Frances WPCP, Process, Primary Treatment, Primary Sludge Degritting	PM	Inspection	1	MONTHS	Teacup Centrifuge Inspection/Service (1m/3m/1y) 1103	COMP	9/1/21 12:00 AM	9/29/21 07:00 AM	9/29/21 08:00 AM	
2446602			1103, Fort Frances WPCP	PM	Refurbish/Replace/Repair	1	YEARS	Air Handling Units Inspection/Service (1y) 1103	COMP	9/1/21 12:00 AM	10/3/21 03:11 PM	10/3/21 03:11 PM	Air Handling Units Inspection/Service (1y) 1103 -Replaced all air filters, greased bearings and replaced belts. KC
2454273			Fort Frances Water Pollution Control Plant	CALL	Refurbish/Replace/Repair	0		Longitudinal collector number 2 failure call in	COMP		9/20/21 03:35 AM	9/20/21 05:30 AM	Longitudinal collector number 2 failure call in -I was called for a longitudinal collector number 2 failure at 0335 hours September 20, 2021. Once at the plant I acknowledged alarms on SCADA computer and then replaced a broken sheer pin. The clarifier drive started and ran fine. Closed working alone ticket after monitoring for a time.