



**Ontario Clean Water Agency**  
**Agence Ontarienne Des Eaux**

Fort Frances WPCP  
200 McIrvine Rd  
PO Box 712  
Fort Frances, Ontario  
P9A 3N1  
Tel: 807-274-3121  
Fax: 807-274-8381



July 17, 2013

Town of Fort Frances  
320 Portage Avenue  
Fort Frances Ontario  
P9A 3M5

Attention: Mr. Doug Herr  
Environmental and Facilities Superintendent

Dear Doug:

**Re: Fort Frances Wastewater Treatment Facility**  
**June 2013 Monthly Report**

As per the operating agreement, the attached document is the June 2013 monthly report for the Fort Frances Wastewater Treatment Facility.

The report highlights the influent and effluent quality and the process parameters. Additionally, the routine operation and maintenance activities conducted by the operators are summarized.

If you have any questions regarding this report do not hesitate to contact Mr. Larry Wachter – Operations Manager.

Yours truly,

A handwritten signature in black ink, appearing to read "Kelly C".

Kelly Cunningham  
Senior Operator

For Larry Wachter  
Operations Manager

**The Corporation of the Town of Fort Frances  
Wastewater Treatment Plant  
(Sewage Plant)  
June 2013 Monthly Operations Report**

## **INTRODUCTION**

In accordance with the Agreement between the Ontario Clean Water Agency (Operating Authority) and the Town of Fort Frances, the Fort Frances Sewage Treatment Plant is required to prepare a monthly report. This document covers the reporting month of June 2013; the facility performance report summarizes important information regarding the quality of the effluent, wastewater, analytical test results, maintenance operations, and relevant activities of the WWTP.

## **DESCRIPTION OF WORKS**

Capacity of Works	9000 m <sup>3</sup> /day (average flow)
Service Area	Town of Fort Frances and Couchiching Reserve
Service Population	9000
Effluent Receiver	Rainy River
Major Process	Secondary treatment facility complete with a phosphorus removal system; ultra violet disinfection; aerobic sludge stabilization and dewatering

The Fort Frances Sewage Treatment Plant received and operates its operation under *Certificate of Approval Number 3-0049-96-006*, in accordance with Section 53 of the Ontario Water Resources Act. The Certificate of Approval outlines the terms and conditions and the report captures these terms and conditions in the following sections.

## **LABORATORY**

ALS Laboratory Group – Thunder Bay is contracted to conduct the required analytical tests of the influent (raw) and effluent samples; weekly requirement.

## JUNE 2013 EFFLUENT QUALITY

<i>Parameters</i>	<i>Monthly Actual Concentration mg/L</i>	<i>Compliance Criteria Concentration mg/L</i>	<i>Performance Objective Concentration mg/L</i>	<i>Monthly Actual Loading, kg/d</i>	<i>Compliance Criteria Loading kg/d</i>	<i>Performance Objective Loading kg/d</i>
CBOD <sub>5</sub>	3.1 mg/L	25 mg/L	15 mg/L	23.3 kg/d	225 kg/d	135 kg/d
Suspended Solids	8.0 mg/L	25 mg/L	15 mg/L	80.8 kg/d	225 kg/d	135 kg/d
Total Phosphorus	0.21 mg/L	1.0 mg/L	1.0 mg/L	1.6 kg/d	9 kg/d	9 kg/d
Ammonia as N	1.14 mg/L					
Nitrite as N	0.14 mg/L					
Nitrate as N	4.44 mg/L					
Total Cl <sub>2</sub> Residual		<0.01 mg/L (when in use)				
E-Coli	6.4 count/100 ml (geometric mean )		200 count/100ml (geometric mean )		E-coli not to exceed 150 organisms/100ml (monthly geometric mean density)	
pH			pH range 7.5 to 8.0; average pH was 7.7			
Temperature degrees C			Temperatures ranged from 9.0- 13.0 average temperature of effluent at 11.4			

Compliance criteria are mandatory requirements of the C of A and performance objectives are a goal to be achieved using best reasonable efforts.

## WASTEWATER LIQUID PROCESS

The average daily flow for June was 7561.8 m<sup>3</sup>/day; representing 84% of the design average flow. Total treated flow for the month was 226,855 m<sup>3</sup>. One daily effluent suspended solids result exceeded 25 mg/L when the secondary clarifier was drained.

The Fort Frances WWTP met all effluent compliance criteria for the parameters listed above and additionally was well within the recommended more stringent monthly performance objective levels as outlined in the Certificate of Approval.

## INVENTORY

Chemical	End of Month Status	Units
Hypochlorite	340 +/- @ 7.0% + 600 @ 12%	Litres
Alum	17.0 +/- @ 65 %	Cubic meters
Polymer	15 Bags (375 kg)	Bags (25 kg/bag)

## MAINTENANCE

The operators performed the routine operations and maintenance at the treatment plant and pumping stations. The activities are highlighted as follows:

### Treatment Plant:

- Alternated lead/lag pumps
- Adjusted fluidizing water to head cell and grit snail as needed
- Greased GBT, mechanical bar screen and grit snail. Lubricated drive chain on grit snail and bar screen
- Hot water flushed alum lines
- Regular cleaning of head works EW basket strainer
- Exercised portable generators
- Greased all blowers
- Regular cleaning of seal water strainer TFP 9-5
- Replaced bulbs and acid washed sleeves UV bank A
- Removed grit from head works inlet channel
- Drained, cleaned and inspected teacup. Removed debris from Headcell inlet
- Changed to small pulley blower 1
- Cleaned polymer dilution water flow meter
- Pulled and cleaned grit pump 1
- Greased clarifier drives
- Monorail disconnect linkage was repaired
- Repaired clarifier 2 inlet weir
- Flushed digester level sensor
- Reversed tubing and calibrated raw sewage sampler
- Installed new chicanes on GBT

**Pump Stations:**

- Ran gen sets
- Changed seal water strainers
- Cleaned bar screens
- Replaced capacitor Church Street lift station
- Replaced overload block on pump 3 at Central Avenue lift station
- Pulled and cleaned pump 2 at Strachan lift station

**OPERATIONAL ISSUES**

The facility met all operational requirements for the month.

**SLUDGE SUMMARY**

The volume directed to the gravity belt thickener totaled 566.5 m<sup>3</sup> for the month. Hammond Landscaping (Certificate of Approval Hauler # 11000025801) hauled/transported 193.1 m<sup>3</sup> (average 11.4 m<sup>3</sup>/load) to the agricultural drying bed. The Organic Soil Conditioning site has a valid Certificate of Approval - number S-71048-31.

**COMPLAINTS**

There were no complaints during the report period.

**BY-PASS REPORT(S)**

There were no by-pass events during the report period.

**COMMENTS**

Plant power consumption for the month was 595 (x 180 multiplier) kWh.

Clarifier 2 was drained in order that a shovel that had fallen in during the clarifier inlet channel cleaning could be recovered.

The additional effluent testing that is required as of January 1, 2013 to meet the requirements of the Wastewater Systems Effluent Regulations is now a part of our regular sampling regimen.

**REPORTS**

ALS – Environmental Analytical Reports (on-file at plant)

Fort Frances WPCP Equipment Run Time Report (on-file at plant)

Bypass Report (on-file at plant as per occurrence)

Month	Avg. Day Flow	Max Day Flow	Sewage Flows Year 2013				Usage	Sludge	Removal Efficiency
	m3	m3	Total Treated	Total ByPass	Total Volume	% Plant Capacity	Volume Hauled	CBOD5	
			Volume ML	Volume ML	ML				
January	4781.7	5473	148234		148234	53%	208.6		
February	4686.2	5427	131213		131213	52%	183.5		
March	4576.3	5880	141866		141866	51%	191.0		
April	6452.2	12672	193567		193567	72%	250.1		
May	11001.0	21372	341032	4640.3	345672.3	122%	233.2		
June	7561.8	10741	226855		226855	84%	193.1		
July						0%			
August						0%			
September						0%			
October						0%			
November						0%			
December						0%			
Sum				4640.3	1187407.3		1259.5		
Average	6510		197128		197901	72%	209.9		
Max		21372	341032		345672.3				
C of A	9000	18000							

	CBOD5				Suspended Solids				Total Phosphorus				E. Coli		pH	
	Avg Raw	Avg. Eff.	Avg. Load	Avg Raw	Avg. Eff.	Avg. Load	Avg Raw	Avg. Eff.	Avg. Load	Geo Mean	Monthly	Monthly	Maximum			
Month	CBOD	CBOD	CBOD	S.S	S.S	S.S	T.P	T.P	T.P	Counts	Minimum	Maximum				
	(mg/L)	(mg/L)	(kg/day)	(mg/L)	(mg/L)	(kg/day)	(mg/L)	(mg/L)	(kg/day)	/100ml						
January	78.5	2.1	10.0	125.0	4.2	20.3	2.6	0.26	1.23	5.1	7.4	7.7				
February	93.3	2.5	12.0	166.0	6.7	31.8	3.0	0.27	1.30	7.8	7.3	7.6				
March	70.7	3.4	15.1	139.9	5.8	26.7	2.7	0.31	1.41	4.4	7.3	7.6				
April	53.6	2.7	19.2	143.3	10.2	82.2	2.1	0.3	2.3	22.9	7.4	7.8				
May	23.3	2.2	26.8	65.4	8.9	115.1	1.0	0.3	3.76	16.6	7.6	7.7				
June	47.4	3.1	23.3	118.3	8.0	80.8	1.4	0.21	1.6	6.4	7.5	8.0				
July																
August																
September																
October																
November																
December																
Average	61.1	2.7	17.7	126.3	7.3	59.5	2.1	0.28	1.93	10.5	7.4	7.7				
Max	93.3	3.4	26.8	166	10.2	115.1	3	0.31	3.76	22.9	7.6	8				
C of A		25	225		25	225		1	9	150	6.0	9.5				