

TOWN OF FORT FRANCES
Operations and Facilities Division - Environmental Area - Operations Statistics
(October 2013)



STAFFING:

See Operations Statistics (October) 2013 prepared by M. Strachan, Superintendent of Transportation

OVERTIME HOURS - Equivalent Straight Time Hours

See Operations Statistics (October) 2013 prepared by M. Strachan, Superintendent of Transportation

WATER DISTRIBUTION:

Water Main Breaks:

- Number of water main breaks: None

Hydrant Repairs:

- Number of hydrant repairs: None

Hydrant Replacements:

- Number of hydrant replacements: Two (2)
 - In front of 1317 Idylwild Dr. (HYD 335) and Idylwild Dr. at Lake Rd. (HYD 331)

Hydrant Installations (NEW):

- Number of new hydrant installations: None

Main Valve Repairs:

- Number of water main valve repairs: None

Water Service Breaks:

- Number of water service breaks: One (1)
 - 1711 Colonization Rd. W.

Water Service Repairs:

- Number of water service repairs: One (1)
 - 1035 Cornwall Ave. N.

Water Service Installations (NEW):

- Number of water service installations: None

Water Service Replacements:

- Number of water service replacements: None

Water Service Terminations:

- Number of water service terminations: None

Water Service Turn "Off/On":

- Number of water service turn "Off/On": Thirty-three (33)
 - 1271 Idylwild Dr., 1034 Christie Ave. N., 237 Eighth St. W., 814 Nelson St. (2), 306 Victoria Ave.
 - 1026 Third St. E., 911 Fifth St. E. (2), 401 King's Hwy. (Legion Park), 901 Second St. E., 1000 Calder Dr.
 - 1301 Calder Dr. (2), 800 Calder Dr., 700 McIrvine Rd., 401 King's Hwy. (Cemetery) (2),
 - 1319 Colonization Rd. W. (2), 416 Sixth St. W., 246 Third St. E. (2), 434 First St. E. (2), 237 Fifth St. E.,
 - 230 Third St. W., 1011 Front St., 1108 Second St. E., 622 Third St. W., 1702 Colonization Rd. W.,
 - 333 Church St. (2)

Frozen Water Services:

- Number of frozen water services: None

Water Meter Installations/Replacements:

- Number of water meter installations/replacements: None

Backflow Preventer Installations/Replacements:

- Number of backflow preventer installations/replacements: None

Backflow Preventer Annual Testing:

- Number of backflow preventer tested: One (1)
 - 675 Flinders Ave.

Other Information:

- Summarized final costs for invoicing of private works associated with private works
- October 1 & 2, 2013 - Completed Lead Testing - Period 2 (June 15 - October 15)
- October 16 - 22, 2013 - Winterized the water system at Sunny Cove Children's Camp.
- October 30 - 31, 2013 - P. Lemesurier & B. Webb received training in the use of the handheld unit (FW950). for use in activating and trouble shooting water meter communication protocols. Training by Elster Canada Inc.
- October 24 - 25, 2013 - G. Wiedenhoeft and D. Herr attended the Northwestern Ontario Water & Wastewater Conference in Thunder Bay.
- Continued with the valve turning program (Area 3) and hydrant valve exercising.
- Began winterizing of the fire hydrant (flush and pump barrels).
- Recorded locations of curb stops at various locations.

WATER TREATMENT PLANT:

- October, 2013 - In receipt of the Water Treatment Plant Monthly Report
- October 1, 2013 - Completed Lead Testing - Period 2 (June 15 - October 15)
- October 16 & 21, 2013 - Winterized the Sunny Cove Camp's water system
- October 23, 2013 - R. White & B. Webb attended a Drinking Water Sampling Techniques & Testing course at Bare Point Water Treatment Plant, Thunder Bay, Ontario.
- October 24 - 25, 2013 - R. White and B. Webb attended the Northwestern Ontario Water & Wastewater Conference in Thunder Bay.

SEWERAGE COLLECTION:

Wastewater Main Backups:

- Number of wastewater main backups: None

Wastewater Main Repairs:

- Number of wastewater main repairs: One (1)
 - Fifth St. E. - 1200 blk. (Forcemain)

Sewer Manhole Repairs:

- Number of sewer manhole repairs: None

Sewer Service Repairs:

- Number of sewer service repairs: One (1)
 - 705 Scott St.

Sewer Service Replacements:

- Number of sewer service replacements: None

Sewer Service Installations (NEW):

- Number of sewer service installations: None

Sewer Service Terminations:

- Number of sewer service terminations: None

Other Information:

- Cleaned Seven (7) plugged sewer services at the following locations:
 - 1049 Colonization Rd. W., 1200 Second St. E., 930 Sixth St. W., 424 King's Hwy., 905 Frenette Ave.
 - 1232 Colonization Rd. W. and 540 Second St. E.
- Winterized dead-end (shallow) sanitary manholes.
- CCTV inspected various building sewer services.
- Recorded locations of cleanouts at various locations.
- Sewer main flushing (Dead Ends) - Areas 11 and 12.
- Sewer service connection inspection at 814 Nelson St.

WASTE-WATER TREATMENT FACILITY:

- October, 2013 - In receipt of the Wastewater Treatment Facility Monthly Report.

WASTE MANAGEMENT:

Garbage Collection:

- Number of complaints regarding garbage collection:
 - Town - 0 complaints, Asselin's - 4 complaints

Sanitary Landfill (Waste Disposal Site):

Landfill Scales functioning during this period.

- Amount of residential waste delivered to the landfill:
 - 249,880 kgs (259.88 tonnes)
- Amount of ICI waste delivered to the landfill:
 - 415,960 kgs (415.96 tonnes)

Recycling:

- Number of complaints regarding recycled materials:
 - Town - 0 complaints, Asselin's - 0 complaints
- Amount of recycled waste diverted from the landfill:
 - 47,540 kgs (47.54 tonnes) Metro

Prepared By: _____

D. L. H.

Environmental & Facilities Superintendent

Date: _____

03-12-2013