

Workorder Summary Report

Report Start Date: Apr 1, 2020 12:00 AM

Report End Date: Apr 30, 2020 11:59 PM

Location: 1103*

Work Order Type: ADMIN,CALL,CAP,CORR,EMER,OPER,PM

Work Order Class: All Workorder Class

				WorkOrder		PM Schedule		Workorder Details					
WO #	Asset ID	Asset Description	Location Description	Type	Class	FEQ	Units	Work Order Description	Status	Schedule Start	Actual Start	Actual Finsh	WorkLog Detail
1701969	0000227376	PANEL ALARM/ DIALER	1103, Fort Frances WPCP, Process, Process Control & Monitoring	PM	Inspection	1	MONTHS	Critical Alarm/Dialer Testing (1m) 1103	COMP	4/1/20 12:00 AM	4/27/20 11:00 AM	4/27/20 12:00 PM	Monthly Dialer -We test every day at 11 am. Dale Hughes
1701973			1103, Fort Frances WPCP	PM	Refurbish/ Replace/Repair	1	MONTHS	Diesel Gensets Inspection/ Functional Tests (1m) 1103	COMP	4/1/20 12:00 AM	4/16/20 12:53 PM	4/16/20 12:53 PM	Monthly Genset Maint. -I run all lift station and plant gensets underload for 1 hour.
1701989			1103, Fort Frances WPCP	PM	Health and Safety	1	MONTHS	Health And Safety Inspection (1m) 1103	COMP	4/1/20 12:00 AM	4/27/20 08:00 AM	4/27/20 09:00 AM	Monthly H&S -I didn't notice anything during a plant walk around. Dale Hughes
1702000			1103, Fort Frances WPCP	PM	Inspection	1	MONTHS	TPM Inspection/Maintenance (1m) 1103	COMP	4/1/20 12:00 AM	5/3/20 02:42 PM	5/3/20 02:42 PM	
1702362			1103, Fort Frances WPCP	PM	Inspection	1	MONTHS	Blowers/Motors Inspection/Service (1m/3m) 1103	COMP	4/1/20 12:00 AM	4/26/20 09:30 AM	4/26/20 10:30 AM	Monthly Blower Maint. -I greased all blowers and checked air filters. Dale Hughes
1702370	0000246402	CENTRIFUGE GS2-2-1 TEACUP/ GRIT SNAIL	1103, Fort Frances WPCP, Process, Primary Treatment, Primary Sludge Degritting	PM	Inspection	1	MONTHS	Teacup Centrifuge Inspection/ Service (1m/3m/1y) 1103	COMP	4/1/20 12:00 AM	4/26/20 01:00 PM	4/26/20 02:00 PM	Teacup Maint. -I removed the teacup lid and inspected for debris and minimal buildup was found. I then returned the unit to service. Dale Hughes

Workorder Summary Report

Report Start Date: Apr 1, 2020 12:00 AM

Report End Date: Apr 30, 2020 11:59 PM

Location: 1103*

Work Order Type: ADMIN, CALL, CAP, CORR, EMER, OPER, PM

Work Order Class: All Workorder Class

				WorkOrder		PM Schedule		Workorder Details					
WO #	Asset ID	Asset Description	Location Description	Type	Class	FEQ	Units	Work Order Description	Status	Schedule Start	Actual Start	Actual Finsh	WorkLog Detail
1706792	0000246414	TANK PROCESS CLARIFIER SECONDARY CELL #1	1103, Fort Frances WPCP, Process, Secondary Treatment	CALL	Refurbish/ Replace/Repair	0		Clarifier collector fail call in April 3 1103	COMP		4/3/20 07:45 PM	4/3/20 09:15 PM	Clarifier collector fail call in April 3 1103 - I was called by the auto dialer at 1945 hours for a clarifier collector failure. I called Communique Action and drove to the plant where I acknowledged the alarm and investigated the failure. The shearpin for longitudinal collector 1 was broken so I replaced it and was able to restart the equipment successfully. Closed ticket and left for home. The shearpin for this collector drive has failed multiple times already in 2020. The other 3 drives have had virtually no incidents. This may very well be indicating that replacement of the chain, sprockets and other parts prone to wear is required in the very near future.