

TOWN OF FORT FRANCES
Operations and Facilities Division - Environmental Area - Operations Statistics
(November 2017)

STAFFING:

See Operations Statistics (November) 2017 prepared by M. Strachan, Superintendent of Transportation

OVERTIME HOURS - Equivalent Straight Time Hours

See Operations Statistics (November) 2017 prepared by M. Strachan, Superintendent of Transportation

WATER DISTRIBUTION:

Water Main Breaks:

- Number of water main breaks: One (1)
- In front of 540 Webster Ave.

Hydrant Repairs:

- Number of hydrant repairs: None

Hydrant Replacements:

- Number of hydrant replacements: None

Hydrant Installations (NEW):

- Number of new hydrant installations: None

Main Valve Repairs:

- Number of water main valve repairs: None

Water Service Breaks:

- Number of water service breaks: None

Water Service Repairs:

- Number of water service repairs: Two (2)
- 1201 Idylwild Dr. and 634 Third St. W.

Water Service Installations (NEW):

- Number of water service installations: None

Water Service Replacements:

- Number of water service replacements: One (1)
- 130 Fifth St. E.

Water Service Terminations:

- Number of water service terminations: None

Water Service Turn "Off/On":

- Number of water service turn "Off/On": Thirty (30)
 - 838 Williams Ave., 1025 River Rd. W., 905 Smith Ave. (2), 613 First St. E. (2), 622 Third St. W.,
 - 1242 Colonization Rd. W., 862 King's Hwy., 331 Second St. E., 1005 Williams Ave., 740 Sixth St. W.
 - 919 Frenette Ave., 838 Third St. E., 928 Frenette Ave., 713 Third St. W., 818 Williams Ave.,
 - 635 King's Hwy. (2), 1201 Idylwild Dr., 912 Sixth St. E., 1144 Second St. E., 121 Oakwood Rd.,
 - 533 Scott St., 638 First St. W., 1533 King's Hwy., 237 Eighth St. W., 638 First St. E.,
 - 1007 Williams Ave. and 634 Second St. W.

Frozen Water Services:

- Number of frozen water services: One (1)
 - 1305 Mill Road (Lakeview Trailer Park - 14 Birch St.)

Water Meter Installations/Replacements:

- Number of water meter installations/replacements: One (1)
 - 121 Oakwood Rd.

Backflow Preventer Installations/Replacements:

- Number of backflow preventer installations/replacements: One (1)
 - 121 Oakwood Rd.

Backflow Preventer Annual Testing:

- Number of backflow preventer tested: One (1)
 - 121 Oakwood Rd.

Other Information:

- Summarized final costs for invoicing of private works associated with private works
- Completed the hydrant flushing/winterizing program.
- Winterizing of the fire hydrants (Private Work).
- Recorded locations of curb stops at various locations.
- November 24, 2017 - Completed a connection inspection of the water service at 130 Fifth St. E.
- November 30, 2017 - Repaired and winterized the hydrant at 520 Eight St. E. (Youth Facility)

WATER TREATMENT PLANT:

- November, 2017 - In receipt of the Water Treatment Plant Monthly Report
- November 1, 2017 - Kirsie McLandress, SAI GLOBAL completed an off-site 24-month surveillance audit of the water system. A part of the accreditation process.
- November 27, 2017 - Devin Ball, Wajax Power System, Thunder Bay complete load testing of the emergency standby generators at Fifth St. E., Central Ave. & White Pine Lift Stations as well as the Portable Unit.

SEWERAGE COLLECTION:

Wastewater Main Backups:

- Number of wastewater main backup: None

Wastewater Main Repairs:

- Number of wastewater main repairs: None

Sewer Manhole Repairs:

- Number of sewer manhole repairs: None

Sewer Service Repairs:

- Number of sewer service repairs: None

Sewer Service Installations (NEW):

- Number of sewer service installations: One (1)
 - 130 Fifth St. E.

Sewer Service Terminations:

- Number of sewer service terminations: None

Sewer Service Replacements:

- Number of sewer service installations: None

Other Information:

- Cleaned Ten (10) plugged sewer services at the following locations:
 - 637 Second St. E., 424 First St. E., 1041 Walker Ave., 650 Church St., 418 Nelson St.
 - 513 Crowe Ave., 525 Portage Ave., 315 Third St. E., 235 McIrvine Rd. and 570 Scott St.
- Sewer main flushing (Dead Ends and Trouble Areas)
- CCTV inspected building sewer service at 237 Church St.
- Commenced winterizing dead-end (shallow) sanitary manholes.
- Completed a connection inspection of the sanitary sewer service at 315 Third St. E. and 130 Fifth St. E.
- New manhole base and pump installed in the Portage Ave. Underpass Pumping Station.
- Recorded locations of cleanouts at various locations.

WASTE-WATER TREATMENT FACILITY:

- November, 2017 - In receipt of the Wastewater Treatment Facility Monthly Report.
- November 29 & 30, 2017 - Devin Ball, Wajax Power System, Thunder Bay complete load testing of the emergency standby generators at Fifth St. E., Central Ave. & White Pine Lift Stations as well as the Portable Unit.
- November 2017 - Town excepted sewage from New Gold (395.56 cu. m.)

WASTE MANAGEMENT:

Garbage Collection:

- Number of complaints regarding garbage collection:
 - Town - 0 complaints, Asselin's - 5 complaints

Sanitary Landfill (Waste Disposal Site):

Landfill Scales functioning good during this period.

- Amount of residential waste delivered to the landfill:
 - 140,360 kgs (140.26 tonnes)
- Amount of ICI waste delivered to the landfill:
 - 221,800 kgs (221.80 tonnes)
- November 4, 2017 - Free tipping for yard wood waste (65 vehicles)

Recycling:

- Number of complaints regarding recycled materials:
 - Town - 0 complaints, Asselin's - 0 complaints
- Amount of recycled waste diverted from the landfill:
 - Emterra: October - 44.09 tonnes & November 47.58 tonnes

Prepared By: _____ Environmental & Facilities Superintendent

Date: _____