

**TOWN OF FORT FRANCES**  
**Operations and Facilities Division - Environmental Area - Operations Statistics**  
**November-21**

**STAFFING:**

See Operations Statistics prepared by M. Strachan, Superintendent of Transportation

**OVERTIME HOURS - Equivalent Straight Time Hours**

See Operations Statistics prepared by M. Strachan, Superintendent of Transportation

**WATER DISTRIBUTION & WASTE WATER COLLECTION:**

Finished winterizing hydrants (including private hydrants)  
3 business running water for winter to prevent frozen water lines  
Lowered sanitary manholes to grade  
Replaced fire hydrant at 5th and Lillie that was out of service.  
Multiple water off's for snowbirds and houses needing repairs  
Pulled sewer mains  
Several plugged sewers and cctv's of sewer lines.  
Plugged sewer main on 4th Street West - vacuumed out.  
Plugged sewer main on Crowe Ave - vacuumed out.

**WATER TREATMENT PLANT:**

In receipt of the Water Treatment Facility Monthly Report.  
Commenced external DWQMS audit  
Negotiations with MECP ongoing for MDWL appeal

**WASTE-WATER TREATMENT FACILITY:**

In receipt of the Wastewater Treatment Facility Monthly Report.  
Standby generator pad construction completed.  
MECP inspection of Landfill on Nov 25. Awaiting report.

**WASTE MANAGEMENT:**

Azimuth Engineering on site early November collecting site information  
November 9th - Landfill Scales back in operation after October lightning strike.

Garbage Collection:

Garbage not picked up - 0

Sanitary Landfill (Waste Disposal Site):

Landfill Scales functioning during this period.

Amount of residential waste (kg) delivered to the landfill:  
See Landfill Report From T. Rob.

Amount of ICI waste (kg) delivered to the landfill:  
See Landfill Report From T. Rob.

Recycling:

Recycle not picked up - 0 houses

Amount of recycled waste (Metric Tonnes) diverted from the landfill:  
38.87 (Emterra)

Prepared By: Craig Miller, P.Eng. Environmental Superintendent

Date: 4-Feb-22