

**June 2022**

**Monthly Summary Report  
Water Systems**

**Prepared by: Greg Wiedenhoeft, ORO  
Senior Water Treatment Plant Operator**

**Dated: July 15, 2022**

### 1) **Introduction:**

This report contains the major maintenance activities and operational events that occurred during the month of June 2022 at the Water Treatment Plant - Water Works # 220000978 and the Airport Groundwater Well Water Works No. 849N7DGE0 (Precedes Airport Groundwater Well Water Works No. 26002736). This information report has been prepared for Council to better understand how the water systems they own and operate are maintained on a monthly basis. Also, this report will assist Council as Directors of the Corporation in exercising its obligation to meet a reasonable Standard of Care as outlined in Section 19 of the Safe Drinking Water Act. The water treatment plant falls under the requirements of Ontario Regulation 170/03 – Drinking Water Systems.

The Airport Small Drinking Water System, System No. 849N7DGE0, was put into service August 01, 2017. The system falls under the requirements of Ontario Regulation 319/08 – Small Drinking Water Systems.

### 2) **Flow Data:**

Water Treatment Plant: See attached spreadsheet.

Airport Groundwater Well:

|                       |         |
|-----------------------|---------|
| Estimated Daily Usage | 0.21 m3 |
| Estimated June Usage  | 6.3 m3  |

### 3) **Microbiological (Health Related) Water Analysis - Main Water System No. 220000978:**

Water Treatment Plant (treated): 4 samples taken no adverse results

Water Treatment Plant (raw): 4 samples taken no adverse results

Water Distribution System: 16 samples taken where 25% of samples were tested for heterotrophic plate count (HPC) - no adverse results.

We take microbiological samples on a weekly basis, which includes 1 raw sample, 1 treated sample and 4 distribution samples. The 4 distribution samples are taken at different locations throughout the distribution system.

Water distribution samples taken at the following locations:

|                     |                      |                      |              |
|---------------------|----------------------|----------------------|--------------|
| 1.835 McKenzie Ave. | 2. 601 Reid Ave.     | 3.1309 King's Hwy.   | 4. W. Tower  |
| 5. 940 Third St. E. | 6. 320 Portage Ave.  | 7. 800 Fifth St. W.  | 8. W. Tower  |
| 9. 943 Third St. E. | 10. 740 Sixth St. W. | 11. 1309 King's Hwy. | 12. W. Tower |
| 13.701 Col. Rd. W.  | 14. 401 King's Hwy.  | 15. 900 Wright Ave.  | 16. W. Tower |

**4) Microbiological (Health Related) Water Analysis - Airport Groundwater Well No. 849N7DGE0:**

New drinking water system put online August 01, 2017. No treatment required as the Airport groundwater tested negative for bacteria.

The Airport drinking water system is to be sampled and tested for bacteria once every three (3) months in accordance with Section 25 – Microbiological Sampling and Testing of the Small Drinking Water Systems Regulation, O. Reg. 319/08.

Water distribution sample taken June 13, 2022 – no adverse results.

**5) Free Available Chlorine Residual (FAC) - Main Water System No. 220000978:**

FAC residuals are taken at a minimum daily at both the Water Treatment Plant and within the Water Distribution System.

**6) Free Available Chlorine Residual (FAC) - Airport Groundwater Well System No. 849N7DGE0:**

New drinking water system put online August 01, 2017. No treatment required as the Airport groundwater well tested negative for bacteria.

**7) Maintenance Activities at the WTP:**

June 01<sup>st</sup> - Calibrated distribution chlorine analyzer.  
-Changed East chlorine tonner.

June 03<sup>rd</sup> - Changed effluent valve actuator and positioner on filter #3.  
- Cleaned effluent valve positioner pin on filter #4.  
- Cleaned top and bottom tanks on poly unit.  
- Cleaned all four (4) check valves on poly pumps.

June 05<sup>th</sup> – Cleaned and flushed poly line to clarifier #1.

June 08<sup>th</sup> - Calibrated distribution chlorine analyzer.

June 09<sup>th</sup> - Cleaned top and bottom tanks on poly unit.  
- Cleaned all four (4) check valves on poly pumps.

June 14<sup>th</sup> - Calibrated distribution chlorine analyzer.

June 17<sup>th</sup> - Cleaned top and bottom tanks on poly unit.  
- Cleaned all four (4) check valves on poly pumps.

June 21<sup>st</sup> – Changed mechanical seal on high lift pump #2.

June 23<sup>rd</sup> - Calibrated fluoride analyzer.

- Cleaned top and bottom tanks on poly unit.
- Cleaned all four (4) check valves on poly pumps.

June 24<sup>th</sup> – Cleaned and flushed poly line to clarifier #1.

- Replaced 16 feet of poly line to clarifier #2.
- Cleaned and flushed poly line to clarifier #2.

June 28<sup>th</sup> - Took grab samples off the filters.

- Ran the generator for 1 hour.

June 30<sup>th</sup> – Cleaned filter #3 turbidity meter probe.

#### 8) **Water Complaints:**

- Poor Pressure – 0 complaints.
- Water quality – 0 complaints.

#### 9) **Other Miscellaneous Information:**

June 06<sup>th</sup> - Routine micro sample collection.

June 07<sup>th</sup> – Received a load of Alum.

- Sent 9 empty fluoride drums back to Brenntag.

June 13<sup>th</sup> - Routine micro sample collection.

- Took quarterly samples at the Water Tower, WTP and Airport.

June 14<sup>th</sup> – Cannect Electric here working on high lift pump #1.

- Cannect Electric here working on backwash pump timer.

June 15<sup>th</sup> – Started cl2 system at the Water Tower.

June 16<sup>th</sup> – Took monthly TSS samples from filter #4.

- Took Landfill test well samples.
- Received 15 drums of fluoride from Brenntag.

June 20<sup>th</sup> - Routine micro sample collection.

June 21<sup>st</sup> - Received 2 chlorine tonners and sent 2 empty tonners back to Brenntag.

June 23<sup>rd</sup> – Took bacti sample at 419 Third St. W. for water service repair.

June 25<sup>th</sup> – Informed SAC, MECP, MOH about the adverse water sample at 419 3<sup>rd</sup>.

June 27<sup>th</sup> - Routine micro sample collection

-Resample at 419 Third St. W. (First sample was an adverse)

June 30<sup>th</sup> – Informed SAC, MECP, MOH (Notice of Issue Resolution)

10) In order to acknowledge that all levels of responsibility within the Corporation of the Town of Fort Frances have received and reviewed this monthly report, it is necessary to sign-off in the appropriate location below:

- Greg Wiedenhoeft, Overall Responsible Operator: Greg Wiedenhoeft
- Craig Miller, P.Eng. Environmental Superintendent: Craig Miller
- Travis Rob, P.Eng. Manager of Operations & Facilities: Travis Rob
- Faisal Anwar, CAO: \_\_\_\_\_
- Rick Wiedenhoeft, Chair O & F Exec Committee: \_\_\_\_\_
- June Caul, Mayor: \_\_\_\_\_
- John McTaggart, Councillor: \_\_\_\_\_
- Mike Behan, Councillor: \_\_\_\_\_
- Wendy Brunetta, Councillor: \_\_\_\_\_
- Doug Judson, Councillor: \_\_\_\_\_
- Andrew Hallikas, Councillor: \_\_\_\_\_

Note: Once all signatures have been obtained, the report will be distributed and made available to the public. If you have any questions, please feel free to contact Greg Wiedenhoeft, Overall Responsible Operator at 807-274-2325.

| Flow Data JUNE                               | Units          | 2020 |         | 2021 |         | 2022 |         |
|--|----------------|------|---------|------|---------|------|---------|
|  |                |      |         |      |         |      |         |
|  |                |      |         |      |         |      |         |
|  |                |      |         |      |         |      |         |
| Total Raw Water                              | m <sup>3</sup> |      | 169000  |      | 178390  |      | 156000  |
| Raw Maximum Day                              | m <sup>3</sup> |      | 6060    |      | 6420    |      | 6040    |
| Raw Minimum Day                              | m <sup>3</sup> |      | 5110    |      | 4930    |      | 4860    |
| Raw Average Daily Consumption                | m <sup>3</sup> |      | 5630    |      | 5950    |      | 5200    |
|  |                |      |         |      |         |      |         |
| Total Treated Water                          | m <sup>3</sup> |      | 115660  |      | 135470  |      | 107220  |
| Treated Water Maximim Day Consumption        | m <sup>3</sup> |      | 5380    |      | 6340    |      | 4530    |
| Treated Water Minimim Day Consumption        | m <sup>3</sup> |      | 2960    |      | 3120    |      | 3030    |
| Treated Water Average Day Consumption        | m <sup>3</sup> |      | 3860    |      | 4520    |      | 3570    |
| Daily Average Per Household Consumption Rate | m <sup>3</sup> |      | 1.020   |      | 1.195   |      | 0.944   |
| * Daily Average Per Person Consumption Rate  | m <sup>3</sup> |      | 0.483   |      | 0.566   |      | 0.447   |
|  |                |      |         |      |         |      |         |
|  |                |      |         |      |         |      |         |
| Monthly Averages - Operating Parameters WTP: |                |      |         |      |         |      |         |
|  |                |      |         |      |         |      |         |
| FAC Residual - Treated Water                 | mg/L           |      | 1.96    |      | 2.19    |      | 1.90    |
| Total Chlorine Residual - Treated Water      | mg/L           |      | 2.21    |      | 2.54    |      | 2.17    |
| Aluminum Sulphate - Raw Water                | mg/L           |      | 37.00   |      | 34.0    |      | 37.0    |
| Aluminum Sulphate - Treated Water Residual   | mg/L           |      | 0.04    |      | 0.03    |      | 0.05    |
| Fluoride - Treated Water                     | mg/L           |      | 0.68    |      | 0.64    |      | 0.66    |
| Soda Ash - Raw Water                         | mg/L           |      | 34.00   |      | 37.0    |      | 36.0    |
| pH - Adjusted                                | mg/L           |      | 6.97    |      | 6.97    |      | 7.03    |
| Temperature                                  | °C             |      | 16.20   |      | 18.0    |      | 13.8    |
|  |                |      |         |      |         |      |         |
| Quantity of Chemical Used:                   |                |      |         |      |         |      |         |
| Aluminum Sulphate                            | kg             |      | 6253    |      | 6065    |      | 5772    |
| Polyelectrolyte                              | kg             |      | 62.50   |      | 87.5    |      | 75.0    |
| Chlorine Gas                                 | kg             |      | 799     |      | 834     |      | 624     |
| Soda Ash - Used for pH Adjustment            | kg             |      | 5746.00 |      | 6600.43 |      | 5616.00 |
| Fluoride                                     | kg             |      | 751     |      | 572     |      | 523     |

\* The Canadian Average is 450 litres (0.45 m<sup>3</sup>) per day.

\* Population is 7986

\* Number of Households is 3783

Town of Fort Frances - Water treatment Plant - Water Works # 220000978  
Monitoring Record  
Jun-22

| Operating Data                            | Units               | *MAC       | 1     | 2     | 3     | 4     | 5     | 6     | 7     | 8     | 9     | 10    | 11    | 12    | 13    | 14    | 15    | 16    | 17    | 18    | 19    | 20    | 21    | 22     | 23    | 24    | 25    | 26    | 27    | 28    | 29    | 30     | Total   | Average |
|---|---------------------|------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|--------|-------|-------|-------|-------|-------|-------|-------|--------|---------|---------|
|   |                     | or Range   |       |       |       |       |       |       |       |       |       |       |       |       |       |       |       |       |       |       |       |       |       |        |       |       |       |       |       |       |       |        |         |         |
| Flow rates                                |                     |            |       |       |       |       |       |       |       |       |       |       |       |       |       |       |       |       |       |       |       |       |       |        |       |       |       |       |       |       |       |        |         |         |
| Raw Water                                 | 1000 m <sup>3</sup> | 17         | 5.50  | 5.06  | 6.04  | 4.91  | 5.25  | 5.35  | 5.16  | 5.17  | 5.18  | 5.15  | 5.09  | 5.23  | 5.09  | 4.96  | 5.16  | 5.21  | 5.19  | 5.06  | 5.14  | 5.21  | 5.56  | 5.15   | 5.19  | 5.00  | 5.26  | 4.99  | 5.30  | 4.86  | 5.44  | 5.14   | 156.00  | 5.20    |
| Peak Instantaneous - Raw Water            | l/s                 | n/a        | 64.68 | 64.78 | 64.98 | 64.76 | 60.48 | 60.41 | 60.51 | 60.41 | 60.31 | 60.34 | 60.71 | 60.80 | 60.89 | 60.66 | 60.74 | 60.68 | 60.50 | 60.64 | 60.65 | 60.55 | 60.47 | 60.51  | 60.74 | 60.64 | 60.99 | 60.79 | 60.16 | 60.18 | 60.24 | 60.14  | 61.11   |         |
| Treated Water                             | 1000 m <sup>3</sup> | 17         | 3.03  | 3.60  | 3.03  | 3.14  | 3.35  | 3.55  | 3.64  | 3.52  | 3.42  | 3.68  | 3.68  | 3.31  | 3.68  | 4.38  | 3.25  | 3.32  | 3.40  | 3.46  | 3.30  | 3.92  | 4.53  | 3.42   | 4.08  | 3.85  | 3.78  | 3.51  | 3.43  | 3.85  | 3.83  | 3.28   | 107.22  | 3.57    |
| Peak Instantaneous - Treated Water        | l/s                 | n/a        | 78.58 | 78.98 | 78.84 | 83.15 | 79.78 | 79.85 | 80.00 | 78.89 | 78.51 | 78.20 | 79.36 | 80.51 | 90.84 | 90.09 | 69.12 | 69.59 | 61.88 | 61.99 | 62.85 | 62.71 | 75.73 | 102.18 | 62.32 | 80.91 | 63.06 | 61.86 | 63.02 | 68.23 | 62.11 | 102.66 | 75.53   |         |
| BackWash Water                            | 1000 m <sup>3</sup> | n/a        | 0.25  | 0.28  | 0.26  | 0.25  | 0.28  | 0.26  | 0.25  | 0.28  | 0.26  | 0.25  | 0.28  | 0.00  | 0.26  | 0.25  | 0.26  | 0.25  | 0.28  | 0.26  | 0.25  | 0.28  | 0.26  | 0.25   | 0.28  | 0.26  | 0.25  | 0.28  | 0.26  | 0.25  | 0.28  | 0.261  | 7.610   | 0.254   |
| Fluoride Information                      |                     |            |       |       |       |       |       |       |       |       |       |       |       |       |       |       |       |       |       |       |       |       |       |        |       |       |       |       |       |       |       |        |         |         |
| Fluoride Residual - Treated Water         | mg/l                | 0.5 to 0.8 | 0.67  | 0.58  | 0.60  | 0.60  | 0.62  | 0.72  | 0.65  | 0.70  | 0.72  | 0.70  | 0.62  | 0.65  | 0.67  | 0.67  | 0.66  | 0.67  | 0.67  | 0.67  | 0.67  | 0.69  | 0.69  | 0.64   | 0.65  | 0.65  | 0.66  | 0.66  | 0.65  | 0.65  | 0.66  | 0.77   | 0.66    |         |
| Turbidity Information                     |                     |            |       |       |       |       |       |       |       |       |       |       |       |       |       |       |       |       |       |       |       |       |       |        |       |       |       |       |       |       |       |        |         |         |
| Raw Water                                 | NTU                 | n/a        | 1.45  | 1.44  | 1.25  | 1.27  | 1.32  | 1.20  | 1.63  | 1.26  | 1.56  | 1.19  | 1.17  | 1.19  | 1.12  | 1.58  | 1.47  | 1.35  | 1.66  | 1.36  | 1.38  | 1.54  | 1.45  | 1.63   | 1.47  | 1.43  | 1.22  | 1.30  | 1.37  | 1.85  | 1.42  | 1.54   | 1.40    |         |
| Settled Water                             | NTU                 | n/a        | 0.17  | 0.13  | 0.15  | 0.10  | 0.13  | 0.13  | 0.11  | 0.11  | 0.13  | 0.12  | 0.09  | 0.13  | 0.17  | 0.16  | 0.13  | 0.13  | 0.14  | 0.14  | 0.13  | 0.14  | 0.10  | 0.11   | 0.09  | 0.08  | 0.11  | 0.08  | 0.12  | 0.14  | 0.10  | 0.16   | 0.12    |         |
| Treated Water                             | NTU                 | 1          | 0.13  | 0.10  | 0.10  | 0.12  | 0.13  | 0.09  | 0.13  | 0.10  | 0.12  | 0.12  | 0.10  | 0.09  | 0.12  | 0.10  | 0.11  | 0.12  | 0.12  | 0.11  | 0.11  | 0.12  | 0.10  | 0.10   | 0.09  | 0.09  | 0.06  | 0.1   | 0.11  | 0.11  | 0.12  | 0.13   | 0.11    |         |
| Other Operating Parameters                |                     |            |       |       |       |       |       |       |       |       |       |       |       |       |       |       |       |       |       |       |       |       |       |        |       |       |       |       |       |       |       |        |         |         |
| pH - Treated Water                        | no units            | 6.5 to 8.5 | 7.10  | 7.06  | 7.03  | 7.03  | 7.09  | 7.15  | 7.02  | 6.98  | 7.04  | 6.99  | 7.03  | 6.99  | 7.01  | 7.00  | 7.03  | 7.08  | 7.05  | 7.04  | 7.02  | 7.03  | 6.98  | 7.06   | 6.97  | 6.96  | 6.99  | 6.98  | 7.00  | 7.04  | 6.97  | 7.03   | 7.03    |         |
| pH - Settled water                        | no units            | n/a        | 6.53  | 6.53  | 6.55  | 6.53  | 6.55  | 6.48  | 6.39  | 6.41  | 6.42  | 6.48  | 6.46  | 6.48  | 6.51  | 6.60  | 6.67  | 6.66  | 6.68  | 6.65  | 6.64  | 6.64  | 6.54  | 6.53   | 6.56  | 6.48  | 6.48  | 6.51  | 6.54  | 6.62  | 6.56  | 6.55   | 6.54    |         |
| pH - Raw Water                            | no units            | n/a        | 6.89  | 6.85  | 6.86  | 6.87  | 6.89  | 6.89  | 6.87  | 6.91  | 6.92  | 6.85  | 6.91  | 6.91  | 6.89  | 6.94  | 6.99  | 6.90  | 6.97  | 6.92  | 6.94  | 6.94  | 6.84  | 6.83   | 6.95  | 6.92  | 6.86  | 6.91  | 6.93  | 7.13  | 6.90  | 6.90   | 6.91    |         |
| FAC - Treated Water                       | mg/l                | 0.2 to 4   | 1.84  | 1.73  | 1.89  | 1.82  | 1.71  | 1.88  | 1.87  | 1.92  | 1.92  | 2.00  | 1.91  | 1.87  | 1.95  | 1.98  | 1.75  | 1.75  | 1.90  | 2.02  | 1.88  | 1.99  | 2.00  | 1.89   | 2.04  | 2.00  | 1.96  | 1.90  | 1.95  | 2.05  | 1.93  | 1.80   | 1.90    |         |
| Total Chlorine Residual Treated           | mg/l                | 0.3 to 7   | 2.16  | 2.00  | 2.09  | 2.02  | 1.88  | 2.02  | 2.15  | 2.19  | 2.20  | 2.19  | 2.06  | 2.18  | 2.17  | 2.24  | 2.06  | 2.04  | 2.14  | 2.30  | 2.19  | 2.31  | 2.33  | 2.20   | 2.31  | 2.25  | 2.25  | 2.20  | 2.12  | 2.38  | 2.34  | 2.24   | 2.17    |         |
| Temperature                               | °C                  | 15         | 10.0  | 11.0  | 11.0  | 11.0  | 12.0  | 12.00 | 12.0  | 12.0  | 12.0  | 13.0  | 13.0  | 14.0  | 14.0  | 14.0  | 14.0  | 14.0  | 14.0  | 14.0  | 14.0  | 15.0  | 15.0  | 15.0   | 15.0  | 16.0  | 16.0  | 16.0  | 16.0  | 17.0  | 17.0  | 13.8   |         |         |
| Fluoride used (Total Daily Consumption)   | kg                  | n/a        | 20.0  | 21.0  | 21.0  | 17.0  | 18.0  | 18.00 | 17.0  | 18.0  | 20.0  | 20.0  | 19.0  | 19.0  | 17.0  | 16.0  | 16.0  | 15.0  | 13.0  | 14.0  | 15.0  | 15.0  | 17.0  | 15.0   | 16.0  | 15.0  | 15.0  | 15.0  | 16.0  | 24.0  | 26.0  | 523.00 | 17.4    |         |
| Chlorine used (Total Daily Consumption)   | kg                  | n/a        | 21.0  | 20.0  | 22.0  | 18.0  | 19.00 | 20.0  | 20.0  | 20.0  | 21.0  | 20.0  | 20.0  | 20.0  | 21.0  | 20.0  | 20.0  | 20.0  | 21.0  | 21.0  | 21.0  | 22.0  | 22.0  | 21.0   | 22.0  | 21.0  | 22.0  | 21.0  | 22.0  | 21.0  | 23.0  | 22.0   | 624.00  | 20.8    |
| Soda Ash (Total Daily Consumption)        | kg                  | n/a        | 198.0 | 182.2 | 217.4 | 176.8 | 189.0 | 192.6 | 185.8 | 186.1 | 186.5 | 185.4 | 183.2 | 188.3 | 183.2 | 178.6 | 185.8 | 187.6 | 186.8 | 182.2 | 185.0 | 187.6 | 200.2 | 185.4  | 186.8 | 180.0 | 189.4 | 179.6 | 190.8 | 175.0 | 195.8 | 185.0  | 5616.00 | 187.2   |
| Soda Ash - Dosage                         | mg/l                | n/a        | 36.0  | 36.0  | 36.0  | 36.0  | 36.0  | 36.0  | 36.0  | 36.0  | 36.0  | 36.0  | 36.0  | 36.0  | 36.0  | 36.0  | 36.0  | 36.0  | 36.0  | 36.0  | 36.0  | 36.0  | 36.0  | 36.0   | 36.0  | 36.0  | 36.0  | 36.0  | 36.0  | 36.0  | 36.0  | 36.0   | 36.0    |         |
| Alum residual - (Total Daily Consumption) | kg                  | n/a        | 203.5 | 187.2 | 223.5 | 181.7 | 194.3 | 198.0 | 190.9 | 191.3 | 191.7 | 190.6 | 188.3 | 193.5 | 188.3 | 183.5 | 190.9 | 192.8 | 192.0 | 187.2 | 190.2 | 192.8 | 205.7 | 190.6  | 192.0 | 185.0 | 194.6 | 184.6 | 196.1 | 179.8 | 201.3 | 190.2  | 5772.00 | 192.4   |
| Alum residual - Dosage                    | mg/l                | n/a        | 37.0  | 37.0  | 37.0  | 37.0  | 37.0  | 37.0  | 37.0  | 37.0  | 37.0  | 37.0  | 37.0  | 37.0  | 37.0  | 37.0  | 37.0  | 37.0  | 37.0  | 37.0  | 37.0  | 37.0  | 37.0  | 37.0   | 37.0  | 37.0  | 37.0  | 37.0  | 37.0  | 37.0  | 37.0  | 37.0   | 37.0    |         |
| Alum residual - Treated Water             | mg/l                | 0.1        | 0.01  | 0.08  | 0.04  | 0.03  | 0.03  | 0.03  | 0.04  | 0.05  | 0.04  | 0.06  | 0.05  | 0.06  | 0.05  | 0.07  | 0.08  | 0.08  | 0.05  | 0.07  | 0.07  | 0.06  | 0.04  | 0.04   | 0.04  | 0.04  | 0.03  | 0.02  | 0.01  | 0.07  | 0.05  | 0.05   | 0.05    |         |
| Poly bags added (25 kg bags )             | kg                  | n/a        |       |       | 0.5   |       |       | 0.5   |       |       |       | 0.5   |       |       |       |       |       |       | 0.5   |       |       |       |       | 0.5    |       |       |       |       |       |       | 0.5   | 75.0   |         |         |

\* MAC - maximum acceptable range

Signature: Greg Wiedenhoeft  
Greg Wiedenhoeft (Jul 27, 2022 07:37 CDT)  
Email: gwiedenhoeft@fortfrances.ca

Signature: Cathy  
Email: cmiller@fortfrances.ca

Signature: Troy  
Email: trob@fortfrances.ca

| Minimum | Maximum |
|---------|---------|
|         |         |
| 4.86    | 6.04    |
| 60.14   | 64.98   |
| 3.03    | 4.53    |
| 61.86   | 102.66  |














# June 2022 WTP Report

Final Audit Report

2022-07-27

|                 |  |
|-----------------|--|
| Created:        | 2022-07-27                                   |
| By:             | Craig Miller (cmiller@fortfrances.ca)        |
| Status:         | Signed                                       |
| Transaction ID: | CBJCHBCAABAAKBH3koBHpMJU-jn7PoFF4z0nN8WsSkHy |

## "June 2022 WTP Report" History

-  Document created by Craig Miller (cmiller@fortfrances.ca)  
2022-07-27 - 12:18:41 PM GMT- IP address: 216.211.31.9
-  Document emailed to gwiedenhoeft@fortfrances.ca for signature  
2022-07-27 - 12:19:11 PM GMT
-  Email viewed by gwiedenhoeft@fortfrances.ca  
2022-07-27 - 12:36:13 PM GMT- IP address: 216.211.31.9
-  Signer gwiedenhoeft@fortfrances.ca entered name at signing as Greg Wiedenhoeft  
2022-07-27 - 12:37:40 PM GMT- IP address: 216.211.31.9
-  Document e-signed by Greg Wiedenhoeft (gwiedenhoeft@fortfrances.ca)  
Signature Date: 2022-07-27 - 12:37:41 PM GMT - Time Source: server- IP address: 216.211.31.9
-  Document emailed to Craig Miller (cmiller@fortfrances.ca) for signature  
2022-07-27 - 12:37:43 PM GMT
-  Email viewed by Craig Miller (cmiller@fortfrances.ca)  
2022-07-27 - 1:11:36 PM GMT- IP address: 216.211.31.9
-  Document e-signed by Craig Miller (cmiller@fortfrances.ca)  
Signature Date: 2022-07-27 - 1:11:54 PM GMT - Time Source: server- IP address: 216.211.31.9
-  Document emailed to Travis Rob (trob@fortfrances.ca) for signature  
2022-07-27 - 1:11:55 PM GMT
-  Email viewed by Travis Rob (trob@fortfrances.ca)  
2022-07-27 - 1:12:26 PM GMT- IP address: 206.125.200.234
-  Document e-signed by Travis Rob (trob@fortfrances.ca)  
Signature Date: 2022-07-27 - 1:19:13 PM GMT - Time Source: server- IP address: 206.125.200.234

✔ Agreement completed.

2022-07-27 - 1:19:13 PM GMT



**Adobe Acrobat Sign**