

Workorder Summary Report

Report Start Date: May 1, 2018 12:00 AM

Report End Date: May 31, 2018 11:59 PM

Location: 1103*

Work Order Type: ADMIN,CALL,CAP,CORR,EMER,OPER,PM

Work Order Class:

				WorkOrder		PM Schedule		Workorder Details					
WO #	Asset ID	Asset Description	Location Description	Type	Class	FEQ	Units	Work Order Description	Status	Schedule Start	Actual Start	Actual Finsh	WorkLog Detail
780842	0000246422	METER LEVEL MULTIRANGER PLUS	1103, Church Pumping Station, Process	CALL	Refurbish/ Replace/Repair	0		church street lift station high level alarm - org 1103	COMP		5/8/18 11:30 PM	5/9/18 01:15 AM	church street lift station high level alarm call out - Received alarm call at 2320, opened working alone ticket and then drove to plant. Checked lift station status via scada, cleared alarms and observed several completed communications cycles. Drove to the lift station and checked to ensure there was no apparent problem with the radio antennae. Returned home and then closed working alone ticket.
782558	0000227421	PUMP CENT VERTICAL NON CLOG SEWAGE P1 FIFTH ST	1103, 5th St. Pumping Station, Process	CALL	Refurbish/ Replace/Repair	0		fift street high level alarm-org 1103	COMP		5/25/18 07:15 PM	5/25/18 09:15 PM	fifth street high level alarm call out - received alarm call at 1920 opened working alone ticket and drove to the plant arriving at 1945 reviewed fifth street pumping station status via scada and found all three pumps running with no flow indicated determined that pumps must be air locked drove to fifth street pumping station and relieved the air lock conditions returned to the plant and monitored fifth street for a complete pump cycle returned home and then closed working alone ticket at approximately 2115

Workorder Summary Report

Report Start Date: May 1, 2018 12:00 AM

Report End Date: May 31, 2018 11:59 PM

Location: 1103*

Work Order Type: ADMIN,CALL,CAP,CORR,EMER,OPER,PM

Work Order Class:

				WorkOrder		PM Schedule		Workorder Details					
WO #	Asset ID	Asset Description	Location Description	Type	Class	FEQ	Units	Work Order Description	Status	Schedule Start	Actual Start	Actual Finsh	WorkLog Detail
782645			1103, Fort Frances WPCP, Facility, Power Generation	CALL	Refurbish/ Replace/Repair	0		plant power failure - org 1103	COMP		5/28/18 12:15 AM	5/28/18 02:30 AM	plant power failure alarm call out - received alarm call at 0020 opened working alone ticket drove to pant arriving at approximately 0045 plant power was out - no apparent reason for the power failure there was power to the main breaker reset main breaker and restored power to the plant reset all alarms and monitored operation of plant until 0145 returned home and closed working alone ticket
780122	0000129835	METER LEVEL	1103, 5th St. Pumping Station, Process	CALL	Refurbish/ Replace/Repair	0		High level alarm 5th St. call in 1103	COMP		5/3/18 03:56 PM	5/3/18 06:00 PM	High level alarm 5th St. call in 1103 -At 1556 I was called by the auto dialer for a 5th St. high level alarm. I opened a ticket and drove to the wastewater plant, arriving at 1625. I acknowledged the alarm on SCADA and drove to the station where I had to address 3 air locked pumps. Once the level in the wet well was pumped down I monitored for several pump cycles before closing my ticket at 1800.
782227			Fort Frances Water Pollution Control Plant	CALL	Refurbish/ Replace/Repair	0		Plant power failure 1103 call in May 22	COMP		5/22/18 03:30 PM	5/22/18 04:05 PM	Plant power failure 1103 call in May 22 -I was called by the auto dialer for a plant power failure at 1530 hours. I called Communique Action and drove to the wastewater plant. Once on site I acknowledged the alarms and was able to reset the phase loss and restore power. I monitored process and closed my ticket and headed home.
775488	0000227376	PANEL ALARM/ DIALER	1103, Fort Frances WPCP, Process, Process Control & Monitoring	PM	Inspection	1	MONTHS	Critical Alarm/Dialer Testing (1m) 1103	COMP	5/1/18 12:00 AM	5/31/18 10:00 AM	5/31/18 11:00 AM	Dialer Test -We test the dialer daily at 10 AM.

Workorder Summary Report

Report Start Date: May 1, 2018 12:00 AM

Report End Date: May 31, 2018 11:59 PM

Location: 1103*

Work Order Type: ADMIN,CALL,CAP,CORR,EMER,OPER,PM

Work Order Class:

				WorkOrder		PM Schedule		Workorder Details					
WO #	Asset ID	Asset Description	Location Description	Type	Class	FEQ	Units	Work Order Description	Status	Schedule Start	Actual Start	Actual Finsh	WorkLog Detail
775492			1103, Fort Frances WPCP	PM	Refurbish/ Replace/Repair	1	MONTHS	Diesel Gensets Inspection/ Functional Tests (1m) 1103	COMP	5/1/18 12:00 AM	5/22/18 10:00 AM	5/22/18 11:00 AM	Monthly Gensets -I ran all gensets under load for one hour and we also had Fort Frances Peterbilt replace fuel filters on all lift station gensets.
775509			1103, Fort Frances WPCP	PM	Health and Safety	1	MONTHS	Health And Safety Inspection (1m) 1103	COMP	5/1/18 12:00 AM	5/25/18 07:00 AM	5/25/18 08:00 AM	May H&S -Still outstanding construction issues and a paper copy on file at the plant.
775526			1103, Fort Frances WPCP	OPER	Compliance	1	MONTHS	WISKI Review (1m) 1103	COMP	5/1/18 12:00 AM	6/2/18 08:00 AM	6/2/18 09:00 AM	WISKI Data Check -I checked WISKI and were still missing some lab data to complete the month.
775879			1103, Fort Frances WPCP	PM	Inspection	1	MONTHS	Blowers/Motors Inspection/Service (1m/3m) 1103	COMP	5/1/18 12:00 AM	5/31/18 09:00 AM	5/31/18 11:00 AM	Blower oil changes -I changed oil in all blowers and greased all blowers.
775887	0000246402	CENTRIFUGE GS2-2-1 TEACUP/ GRIT SNAIL	1103, Fort Frances WPCP, Process, Primary Treatment, Primary Sludge Degritting	PM	Inspection	1	MONTHS	Teacup Centrifuge Inspection/ Service (1m/3m/1y) 1103	COMP	5/1/18 12:00 AM	5/24/18 02:00 PM	5/24/18 03:00 PM	Monthly Teacup Maint -I locked out the unit then removed the lid and inspected, To find no debris . I then hosed down the unit and replaced the lid and returned it to service.