

Workorder Summary Report

Report Start Date: Apr 1, 2022 12:00 AM

Report End Date: Apr 30, 2022 11:59 PM

Location: 1103*

Work Order Type: ADMIN,CALL,CAP,CORR,EMER,OPER,PM

Work Order Class:

				WorkOrder		PM Schedule		Workorder Details					
WO #	Asset ID	Asset Description	Location Description	Type	Class	FEQ	Units	Work Order Description	Status	Schedule Start	Actual Start	Actual Finsh	WorkLog Detail
2753034			1103, Fort Frances WPCP	OPER	Inspection	1	MONTHS	Snow Removal at Wastewater Treatment (1m) 1103	COMP	4/1/22 12:00 AM	5/2/22 02:27 PM	5/2/22 02:27 PM	Snow Removal - Plowed snow and shoveled walkways at plant
2768428	0000227376	PANEL ALARM/DIALER	1103, Fort Frances WPCP, Process, Process Control & Monitoring	PM	Inspection	1	MONTHS	Critical Alarm/Dialer Testing (1m) 1103	COMP	4/1/22 12:00 AM	5/2/22 02:32 PM	5/2/22 02:32 PM	Critical Alarm/Dialer Testing (1m) 1103 - We test the dialler automatically everyday.
2768432			1103, Fort Frances WPCP	PM	Refurbish/Replace/Repair	1	MONTHS	Diesel Gensets Inspection/Functional Tests (1m) 1103	COMP	4/1/22 12:00 AM	4/22/22 08:57 AM	4/22/22 08:57 AM	Diesel Gensets Inspection/Functional Tests (1m) 1103 - The Town is still in process of ordering a new portable diesel genset. Peterbilt started and ran genset at Fifth Street for troubleshooting purposes.Peterbilt has ordered 2 parts for the genset at Fifth Street lift station. Ran gensets at Central Avenue and White Pine lift stations.
2768459			1103, Fort Frances WPCP	PM	Inspection	1	MONTHS	TPM Inspection/Maintenance (1m) 1103	COMP	4/1/22 12:00 AM	5/2/22 02:33 PM	5/2/22 02:33 PM	
2768809	0000246402	CENTRIFUGE GS2-2-1 TEACUP/GRIT SNAIL	1103, Fort Frances WPCP, Process, Primary Treatment, Primary Sludge Degritting	PM	Inspection	1	MONTHS	Teacup Centrifuge Inspection/Service (1m/3m/1y) 1103	COMP	4/1/22 12:00 AM	4/28/22 09:52 AM	4/28/22 09:52 AM	Teacup Centrifuge Inspection/Service (1m/3m/1y) 1103 - Lubricated bearings and drive chain on grit snail
2772868	0000246436	PANEL CONTROL PCL	1103, Boundary Pumping Station, Facility	CALL	Refurbish/Replace/Repair	0		Boundary Road high level alarm call in	COMP		4/5/22 02:30 AM	4/5/22 04:00 AM	Boundary Road high level alarm call in - I was called by the auto dialer for a Boundary Road lift station high level alarm at 0230 hours. I drove to the plant where I was able to acknowledge and reset alarms on the SCADA computer. 2 other alarms came in at the same time so it seems that there was a PLC glitch at the time. The station has returned to a normal state of operation

Workorder Summary Report

Report Start Date: Apr 1, 2022 12:00 AM

Report End Date: Apr 30, 2022 11:59 PM

Location: 1103*

Work Order Type: ADMIN,CALL,CAP,CORR,EMER,OPER,PM

Work Order Class:

				WorkOrder		PM Schedule		Workorder Details					
WO #	Asset ID	Asset Description	Location Description	Type	Class	FEQ	Units	Work Order Description	Status	Schedule Start	Actual Start	Actual Finsh	WorkLog Detail
2773344	0000129937	PANEL CONTROL LEVEL/ALARM	1103, Central Ave Pumping Station, Facility	CALL	Refurbish/ Replace/Repair	0		Central Avenue high level alarm call in 1103	COMP		4/6/22 05:15 PM	4/6/22 08:00 PM	Central Avenue high level alarm call in 1103 - I was called for a Central Avenue lift station high level alarm at 1715 hours. I drove to the station where I acknowledged the alarms on the panel and then got some air out of pump 3 to improve pumping. The level came back down and I monitored the operation until 2000 hours.
2773346	0000227438	PUMP CENT VERTICAL NON CLOG SEWAGE #2 P2 CENTRAL	1103, Central Ave Pumping Station, Process	CALL	Refurbish/ Replace/Repair	0		Central Avenue pump fail/high level alarm call in 1103	COMP		4/7/22 12:00 AM	4/7/22 03:30 AM	Central Avenue pump fail/high level alarm call in 1103 - I was called for Central Avenue lift station pump fail and high level alarms at 2350 hours yesterday. When I arrived at the station I realized that I would need assistance, so I called Dale Hughes at 0000 hours. We then proceeded to isolate , pull and clean the 3 pumps. We were back at the plant to clean up at 0320 hours.
2773375	0000227434	PUMP CENT VERTICAL NON CLOG SEWAGE P1 CENTRAL	1103, Central Ave Pumping Station, Process	CALL	Refurbish/ Replace/Repair	0		Central Pump Faults 1103	COMP		4/7/22 12:01 PM	4/7/22 12:06 PM	Central Pump Faults - Called in to assist Kelly to pull all 3 pumps at Central lift station.
2775597	0000129851	PUMP SUBMERSIBLE 11-1	1103, Fort Frances WPCP, Process	CALL	Refurbish/ Replace/Repair	0		Plant basement sump high level alarm call in 1103	COMP		4/17/22 11:35 PM	4/18/22 01:30 AM	Plant basement sump high level alarm call in 1103 - I was called by the auto dialer for a sump high level alarm at 2335 hours. I drove to the plant where I acknowledged the alarms on the SCADA computer and then reset the fault on the local pump panel.

Workorder Summary Report

Report Start Date: Apr 1, 2022 12:00 AM

Report End Date: Apr 30, 2022 11:59 PM

Location: 1103*

Work Order Type: ADMIN,CALL,CAP,CORR,EMER,OPER,PM

Work Order Class:

				WorkOrder		PM Schedule		Workorder Details					
WO #	Asset ID	Asset Description	Location Description	Type	Class	FEQ	Units	Work Order Description	Status	Schedule Start	Actual Start	Actual Finsh	WorkLog Detail
2776755	0000129811	METER LEVEL MILLTRONIC BYPASS FLOW	1103, Fort Frances WPCP, Process, Process Control & Monitoring	CALL	Refurbish/ Replace/Repair	0		Plant bypass call in 1103	COMP		4/22/22 06:00 PM	4/22/22 10:00 PM	Plant bypass call in 1103 - I was called in at 1800 hours on April 22, 2022 to assist Dale with a plant bypass at the wastewater treatment plant during a heavy rainfall and snow melt caused event that also included pumping stations at or near capacity. I returned home at 2200 hours to get some rest as this was likely to be an extended event
2776761			1103, White Pine Pumping Station	CALL	Refurbish/ Replace/Repair	0		Flooded White Pine lift station drywell 1103 call in	COMP		4/23/22 05:20 AM	4/24/22 09:20 AM	Flooded White Pine lift station drywell 1103 call in - I was called in to assist Dale after he had found a flooded White Pine drywell so all pumps and wiring was under water. We worked with the Town of Fort Frances crew to get pumps, sucker trucks and related equipment in place to get the surcharged station and collection system back to normal levels and to monitor a plant bypass, UV bypass and rental pump that will be in place at White Pine station until permanent solution is in place.
2776769	0000129811	METER LEVEL MILLTRONIC BYPASS FLOW	1103, Fort Frances WPCP, Process, Process Control & Monitoring	CALL	Refurbish/ Replace/Repair	0		Manhole 8 High Level 1103	COMP		4/24/22 11:20 AM	4/24/22 11:27 AM	Manhole 8 High Level Alarm - Plant was beginning to bypass due to heavy rain event.
2777326			1103, White Pine Pumping Station	CALL	Refurbish/ Replace/Repair	0		White Pine pumps removal re flooded drywell 1103	COMP		4/25/22 10:45 AM	4/25/22 07:45 PM	White Pine pumps removal re flooded drywell 1103 - I was called in to assist Dale re moving portable temporary pump piping with the Town of Fort Frances crew at White Pine lift station as well as the isolation and removal of both pumps from the drywell that had been sucked out by vac truck. FFPC lifted the pumps from the drywell so that we could package them up for shipping out for repair.

Workorder Summary Report

Report Start Date: Apr 1, 2022 12:00 AM

Report End Date: Apr 30, 2022 11:59 PM

Location: 1103*

Work Order Type: ADMIN,CALL,CAP,CORR,EMER,OPER,PM

Work Order Class:

				WorkOrder		PM Schedule		Workorder Details					
WO #	Asset ID	Asset Description	Location Description	Type	Class	FEQ	Units	Work Order Description	Status	Schedule Start	Actual Start	Actual Finsh	WorkLog Detail
2777759	0000129811	METER LEVEL MILLTRONIC BYPASS FLOW	1103, Fort Frances WPCP, Process, Process Control & Monitoring	CALL	Refurbish/ Replace/Repair	0		Manhole 8 High Level 1103	COMP		4/29/22 01:08 PM	4/29/22 01:21 PM	Manhole #8 High Level - I responded to a false alarm of Manhole 8 high level alarm.